



Remarques

1. DEPENDING ON OPERATION AND INSTALLATION CONDITIONS, THE INDOOR UNIT CAN CHANGE OVER TO FREEZE-UP OPERATION (INDOOR DE-ICING).
2. TO REDUCE THE FREEZE-UP OPERATION (INDOOR DE-ICING) FREQUENCY IT IS RECOMMENDED TO INSTALL THE OUTDOOR UNIT IN A LOCATION NOT EXPOSED TO WIND.