






HTXY100NP

INDEX	PART NAME	MATERIAL	QUANTITY	WEIGHT
1	LATERAL PANEL	MAGNELIS	2	14,8 kg
2	ACOUSTIC GRID	MAGNELIS	2	55,1 kg
3	ROOF	MAGNELIS	1	17,2 kg
4	BASEFRAME	PAINTED STEEL	2	12,2 kg
5	OUTDOOR UNIT BRACKET	PAINTED STEEL	2	1,6 kg
6	AIR SEPARATION	P3	1	1,6 kg
7	FLAT WASHER D=8	GALVANIZED STEEL	16	-
8	SPRING WASHER D8	GALVANIZED STEEL	8	-
9	HEX NUT M8	GALVANIZED STEEL	16	-
10	SCREW M8X30 8.8	GALVANIZED STEEL	32	-
11	SILENTBLOCKS M8 D 40X20	STEEL + RUBBER	4	-
12	SELF-DRILLING SCREW 3.5X13	GALVANIZED STEEL	4	-
13	FIXATION PROFILE	MAGNELIS	2	-



Total weight: 190 kg




IN CASE NOT USED, **OUTDOOR UNIT BRACKET** SHOULD BE POSITIONED FULLY TO THE LEFT AND RIGHT FOR MAX. RIGIDITY



* MAX. DIMENSIONS
FOR OUTDOOR UNIT
INSTALLATION

BASEFRAME TOP VIEW DETAIL FOR FIXING

Position to fix to fundament floor



OUTDOOR UNIT BRACKET
(Detail)