





# HTY100NP



| INDEX | PART NAME         | MATERIAL   | QUANTITY | WEIGHT  |
|-------|-------------------|------------|----------|---------|
| 1     | LATERAL PANEL     | MAGNELIS   | 2        | 12,6 kg |
| 2     | ACOUSTIC GRID     | MAGNELIS   | 2        | 37,1 kg |
| 3     | ROOF              | MAGNELIS   | 1        | 14,0 kg |
| 4     | BASEFRAME         | PAINTED    | 2        | 9,6 kg  |
| 5     | OUTDOOR UNIT      | PAINTED    | 2        | 1,6 kg  |
| 6     | AIR SEPARATION    | P3         | 1        | 1,3 kg  |
| 7     | FLAT WASHER D=8   | GALVANIZED | 16       | -       |
| 8     | SPRING WASHER D8  | GALVANIZED | 8        | -       |
| 9     | HEX NUT M8        | GALVANIZED | 16       | -       |
| 10    | SCREW M8X30 8.8   | GALVANIZED | 32       | -       |
| 11    | SILENTBLOCKS M8 D | STEEL +    | 4        | -       |
| 12    | SELF-DRILLING     | GALVANIZED | 4        | -       |
| 13    | FIXATION PROFILE  | MAGNELIS   | 2        | -       |


Total weight: 160 kg

IN CASE NOT USED, **OUTDOOR UNIT BRACKET** SHOULD BE POSITIONED FULLY TO THE LEFT AND RIGHT FOR MAX. RIGIDITY



B-B

\* MAX. DIMENSIONS  
FOR OUTDOOR UNIT  
INSTALLATION



# BASEFRAME TOP VIEW DETAIL FOR FIXING

Position to fix to fundament floor

