





HTY100NPSA

INDEX	PART NAME	MATERIAL	QUANTITY	WEIGHT
1	LATERAL PANEL	MAGNELIS	2	10,7 kg
2	ACOUSTIC GRID	MAGNELIS	1	37,1 kg
3	ROOF	MAGNELIS	1	17,3 kg
4	BASEFRAME	PAINTED	2	12,2 kg
5	OUTDOOR UNIT	PAINTED	2	1,6 kg
6	AIR SEPARATION	P3	1	1,6 kg
7	FLAT WASHER D=8	GALVANIZED	24	-
8	LATERAL ACOUSTIC	MAGNELIS	2	34,1 kg
9	HEX NUT M8	GALVANIZED	16	-
10	SCREW M8X30 8.8	GALVANIZED	42	-
11	SILENTBLOCKS M8 D	STEEL +	4	-
12	SELF-DRILLING SCREW	GALVANIZED	4	-
13	FIXATION PROFILE	MAGNELIS	2	-
14	REAR PANEL	MAGNELIS	1	20,6 kg


Total weight: 190 kg

IN CASE NOT USED, **OUTDOOR UNIT BRACKET** SHOULD BE POSITIONED FULLY TO THE LEFT AND RIGHT FOR MAX. RIGIDITY







* MAX. DIMENSIONS
FOR OUTDOOR UNIT
INSTALLATION



BASEFRAME TOP VIEW
DETAIL FOR FIXING

Position to fix to fundament floor



OUTDOOR UNIT BRACKET
(Detail)