


Project: GripplE Hangers
Client: GripplE Ltd
Client's Order No: 3061
Inspection Date:
First: 06/04/2009


Certificate No: COV 0919097
Office: Sheffield
Date: 20/02/2009
Order Status: Complete
Final: 06/04/2009

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
 Surveyor of Lloyd's Register



GripplE Model	Angle to Horizontal	GripplE Rated Load	GripplE Load Limit 5:1	Result		
No.2 C-Clip	0°	10 - 45 kg 22-99 lbs	225kg 495 lbs	319.8 kg 703.6 lbs	338.3 kg 744.3 lbs	344.7 kg 758.3 lbs
No.2 C-Clip	30°	10 - 45 kg 22-99 lbs	225kg 495 lbs	336.8 kg 741.0 lbs	321.7 kg 707.7 lbs	325.7 kg 716.5 lbs
No.2 C-Clip	60°	10 - 45 kg 22-99 lbs	225kg 495 lbs	329.4 kg 724.7 lbs	330.9 kg 728.0 lbs	338.0 kg 743.6 lbs

GripplE Ltd The Old West Gun Works Savile Street East Sheffield S4 7UQ
 Tel: +44 (0)114 275 2255 Fax: +44 (0)114 275 1155
 www.gripplE.com email: info@gripplE.com