

#### IH 24h

Operating instructions



srm: CCT16364 arm: CCT15365

## For your safety



#### DANGER

Risk of serious damage to property and personal injury, e.g. from fire or electric shock, due to incorrect electrical installation.

Safe electrical installation can only be ensured if the person in question can prove basic knowledge in the following areas:


- · Connecting to installation networks
- · Connecting several electrical devices
- · Laying electric cables

These skills and experience are normally only possessed by skilled professionals who are trained in the field of electrical installation technology. If these minimum requirements are not met or are disregarded in any way, you will be solely liable for any damage to property or personal injury.

### Getting to know IH 24h


IH 24h is a mechanical time switch that switches connected loads on or off when the set time has been reached. It is installed on a DIN rail (DIN EN 60715).

### **Product details**



# Installing IH 24h

- 1) Place the IH 24h onto the DIN rail.
- Connect cables:
  - Remove 8 mm (max. 9 mm) of insulation
- Open the plug-in terminal with a screwdriver and plug in the cable at a 45° angle. (max. 2 cables per plug-in terminal)



Connect the mains voltage



IH 24h arm (art. no. CCT15365) is equipped with a quartz clock mechanism. The quartz clock mechanism only starts after a few minutes after having connected it a power supply. Complete power reserve is reached after 5 days.

#### Setting IH 24h

#### Setting the time

Use the rotary knob to set the time (hour, minutes). You can turn the rotary knob clockwise and anti-clockwise.

To set the time in the morning 3/6/9 must be visible on the clock face.



To set the time in the afternoon, 15/18/21 must be visible on the clock face.






The clock face changes between morning and afternoon times when the dial has gone past 24 and 12 hours.

### Setting the switching time

You can set the switching time using the switching segments. Each switching segment stands for a 15-minute time period. The switching segments can be pushed in or out, for example, by using your index finger. The setting disc shows the switching period (+/- 5 minutes).

Switching segment out Load switched off

Load switched on Switching segment in 1 ∄



## Example times:

Switching time 1 = 6:00 - 10:00


Switching time 2 = 17:00 - 21:00

### Operating IH 24h

## Operating the manual switch

You can switch the load on or off in advance as long as the time switch is on automatic mode (9).

 Turn the manual switch by one position anti-clockwise. The current status is reversed and stays unchanged for



#### Operating the automatic/permanent switch

With the automatic/permanent switch, you can switch the load permanently on or off or permanently set it to automatic mode.

 Activating permanent ON: Set the switch to "1".



The load is switched on permanently. The set switching times are deactivated.

 Activating permanent OFF: Set the switch to "0".

The load is switched off permanently. The set switching times are deactivated.

Activating automatic mode: Set the switch to "clock". The set switching times remain activated. The load is switched on or off when the set switching time has been reached.



For permanent ON or permanent OFF, the set switching times are deactivated.

### Technical data

Nominal voltage:

CCT16364 AC 230 V. 50/ Hz CCT15365 AC 110-230 V, 50-60 Hz

Nominal current: 16 A,  $\cos \varphi = 1$ 

4 A,  $\cos \varphi = 0.6$ 

Incandescent lamps: AC 230 V, max. 1100 W Halogen lamps: AC 230 V max 1000 W Fluorescent tubes: AC 230 V, max. 600 VA

Fluorescent lamps with

2 x 40 W (12 μF), electronic ballast:

parallel-compensated

Compact fluorescent lamps with electronic ballast:

<2 W: 20 W >2 W:180 W

Power consumption: ≈ 0.5 W

-20°C to +55°C Ambient temperature:

Connecting terminals: 2 x 0.5 - max. 2.5 mm<sup>2</sup>.

fixed and flexible wires

Power reserve:

LED lamps:

CCT15365 150 h (230 V),

75 h (110 V)

Accuracy:

CCT16364 Network synchronous CCT15365 ≤±1 s/day at +20°C Mode of operation: srm: Device of 1 BRTU

type in accordance with

EN 60730-1

arm: Device of 1 BSTU type in accordance with

EN 60730-1

Degree of pollution: 2 Rated impulse voltage: 4000 V

Protection class: II per EN 60730-1 when

installed correctly

IP 20 in accordance with Type of protection:

EN 60529

### Schneider Electric Industries SAS

If you have technical questions, please contact the Customer Care Centre in your country.

www.schneider-electric.com