

Wall-Mounted Maintenance Bypass Panel

For Galaxy VS, Easy UPS 3S, and Easy UPS 3M

Installation

GVSBPSU10K20H, GVSBPSU20K60H, GVSBPSU80K120H

6/2022



Legal Information

The Schneider Electric brand and any trademarks of Schneider Electric SE and its subsidiaries referred to in this guide are the property of Schneider Electric SE or its subsidiaries. All other brands may be trademarks of their respective owners.

This guide and its content are protected under applicable copyright laws and furnished for informational use only. No part of this guide may be reproduced or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), for any purpose, without the prior written permission of Schneider Electric.

Schneider Electric does not grant any right or license for commercial use of the guide or its content, except for a non-exclusive and personal license to consult it on an "as is" basis. Schneider Electric products and equipment should be installed, operated, serviced, and maintained only by qualified personnel.

As standards, specifications, and designs change from time to time, information contained in this guide may be subject to change without notice.

To the extent permitted by applicable law, no responsibility or liability is assumed by Schneider Electric and its subsidiaries for any errors or omissions in the informational content of this material or consequences arising out of or resulting from the use of the information contained herein.

Table of Contents

Important Safety Instructions — SAVE THESE	
INSTRUCTIONS	5
Electromagnetic Compatibility	6
Safety Precautions	6
Additional Safety Precautions After Installation.....	8
Electrical Safety.....	8
Specifications	9
Recommended Upstream Protection.....	9
Recommended Cable Sizes	9
Torque Specifications.....	9
Maintenance Bypass Panel Weights and Dimensions.....	9
Clearance	10
Environment.....	10
One Line Diagrams.....	11
Installation Procedure for Galaxy VS UPS.....	14
Installation Procedure for Easy UPS 3S and Easy UPS 3M	16
Mount the Maintenance Bypass Panel to the Wall	17
Prepare the Maintenance Bypass Panel for Cables.....	19
Remove the Neutral Jumpers	20
Connect the Power Cables for a 3:3 UPS System.....	21
Connect the Power Cables for a 3:1 UPS System.....	24
Connect the Signal Cables for Galaxy VS UPS – Single System.....	26
Connect the Signal Cables for Galaxy VS UPS – Simplified 1+1 Parallel System	29
Connect the Signal Cables for Easy UPS 3S and Easy UPS 3M – Single System	36
Add Translated Safety Labels to Your Product.....	39
Final Installation	40

Important Safety Instructions — SAVE THESE INSTRUCTIONS

Read these instructions carefully and look at the equipment to become familiar with it before trying to install, operate, service or maintain it. The following safety messages may appear throughout this manual or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



The addition of this symbol to a “Danger” or “Warning” safety message indicates that an electrical hazard exists which will result in personal injury if the instructions are not followed.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages with this symbol to avoid possible injury or death.

DANGER

DANGER indicates a hazardous situation which, if not avoided, **will result in death or serious injury.**

Failure to follow these instructions will result in death or serious injury.

WARNING

WARNING indicates a hazardous situation which, if not avoided, **could result in death or serious injury.**

Failure to follow these instructions can result in death, serious injury, or equipment damage.

CAUTION

CAUTION indicates a hazardous situation which, if not avoided, **could result in minor or moderate injury.**

Failure to follow these instructions can result in injury or equipment damage.

NOTICE

NOTICE is used to address practices not related to physical injury. The safety alert symbol shall not be used with this type of safety message.

Failure to follow these instructions can result in equipment damage.

Please Note

Electrical equipment should only be installed, operated, serviced, and maintained by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction, installation, and operation of electrical equipment and has received safety training to recognize and avoid the hazards involved.

Electromagnetic Compatibility

NOTICE

RISK OF ELECTROMAGNETIC DISTURBANCE

This is a product category C2 UPS product. In a residential environment, this product may cause radio interference, in which case the user may be required to take additional measures.

Failure to follow these instructions can result in equipment damage.

Safety Precautions

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Read all instructions in the installation manual before installing or working on this product.

Failure to follow these instructions will result in death or serious injury.

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Do not install the product until all construction work has been completed and the installation room has been cleaned.

Failure to follow these instructions will result in death or serious injury.

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

The product must be installed according to the specifications and requirements as defined by Schneider Electric. It concerns in particular the external and internal protections (upstream breakers, battery breakers, cabling, etc.) and environmental requirements. No responsibility is assumed by Schneider Electric if these requirements are not respected.

Failure to follow these instructions will result in death or serious injury.

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

The UPS system must be installed according to local and national regulations. Install the UPS according to:

- IEC 60364 (including 60364-4-41- protection against electric shock, 60364-4-42 - protection against thermal effect, and 60364-4-43 - protection against overcurrent), **or**
- NEC NFPA 70, **or**
- Canadian Electrical Code (C22.1, Part 1)

depending on which one of the standards apply in your local area.

Failure to follow these instructions will result in death or serious injury.

⚠ ⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

- Install the product in a temperature controlled indoor environment free of conductive contaminants and humidity.
- Install the product on a non-flammable, level and solid surface (e.g. concrete) that can support the weight of the system.

Failure to follow these instructions will result in death or serious injury.

⚠ ⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

The product is not designed for and must therefore not be installed in the following unusual operating environments:

- Damaging fumes
- Explosive mixtures of dust or gases, corrosive gases, or conductive or radiant heat from other sources
- Moisture, abrasive dust, steam or in an excessively damp environment
- Fungus, insects, vermin
- Salt-laden air or contaminated cooling refrigerant
- Pollution degree higher than 2 according to IEC 60664-1
- Exposure to abnormal vibrations, shocks, and tilting
- Exposure to direct sunlight, heat sources, or strong electromagnetic fields

Failure to follow these instructions will result in death or serious injury.

⚠ ⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Do not drill or cut holes for cables or conduits with the gland plates installed and do not drill or cut holes in close proximity to the UPS.

Failure to follow these instructions will result in death or serious injury.

⚠ ⚠ WARNING

HAZARD OF ARC FLASH

Do not make mechanical changes to the product (including removal of cabinet parts or drilling/cutting of holes) that are not described in the installation manual.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

NOTICE

RISK OF OVERHEATING

Respect the space requirements around the product and do not cover the ventilation openings when the product is in operation.

Failure to follow these instructions can result in equipment damage.

Additional Safety Precautions After Installation

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Do not install the UPS system until all construction work has been completed and the installation room has been cleaned. If additional construction work is needed in the installation room after this product has been installed, turn off the product and cover the product with the protective packaging bag the product was delivered in.

Failure to follow these instructions will result in death or serious injury.

Electrical Safety

This manual contains important safety instructions that should be followed during the installation and maintenance of the UPS system.

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

- Electrical equipment must be installed, operated, serviced, and maintained only by qualified personnel.
- Apply appropriate personal protective equipment (PPE) and follow safe electrical work practices.
- Disconnection devices for AC and DC must be provided by others, be readily accessible, and the function of the disconnect device marked for its function.
- Turn off all power supplying the UPS system before working on or inside the equipment.
- Before working on the UPS system, check for hazardous voltage between all terminals including the protective earth.
- The UPS contains an internal energy source. Hazardous voltage can be present even when disconnected from the mains supply. Before installing or servicing the UPS system, ensure that the units are OFF and that mains and batteries are disconnected. Wait five minutes before opening the UPS to allow the capacitors to discharge.
- The UPS must be properly earthed/grounded and due to a high leakage current, the earthing/grounding conductor must be connected first.

Failure to follow these instructions will result in death or serious injury.

When the UPS input is connected through external isolators that, when opened, isolate the neutral or when the automatic backfeed isolation is provided external to the equipment or is connected to an IT power distribution system, a label must be fitted at the UPS input terminals, and on all primary power isolators installed remotely from the UPS area and on external access points between such isolators and the UPS, by the user, displaying the following text (or equivalent in a language which is acceptable in the country in which the UPS system is installed):

DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Risk of voltage backfeed. Before working on this circuit: Isolate the UPS and check for hazardous voltage between all terminals including the protective earth.

Failure to follow these instructions will result in death or serious injury.

Specifications

NOTE: Maximum short circuit rating: 10 kA RMS symmetrical.

NOTE: GVSBPUSU80K120H can support a load of up to 120 kW/kVA as long as the neutral current (250 A) is not exceeded:

- at 380 V, the maximum neutral current capability is reached with a 95 kVA non-linear load.
- at 400 V, the maximum neutral current capability is reached with a 100 kVA non-linear load.

Recommended Upstream Protection

Refer to the UPS installation manual for recommended upstream protection.

Recommended Cable Sizes

⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

All wiring must comply with all applicable national and/or electrical codes. The maximum allowable cable size is 16 mm² for GVSBPUSU10K20H, 70 mm² for GVSBPUSU20K60H, and 150 mm² for GVSBPUSU80K120H.

Failure to follow these instructions will result in death or serious injury.

NOTE: Aluminum cables are not supported in a 80-100 kW simplified 1+1 parallel system.

Refer to the UPS installation manual for recommended cable sizes.

Torque Specifications


Bolt size	Torque
M4	1.7 Nm
M5	2.2 Nm
M6	5 Nm
M8	17.5 Nm
M10	30 Nm
M12	50 Nm

Maintenance Bypass Panel Weights and Dimensions

Commercial reference	Weight kg	Height mm	Width mm	Depth mm
GVSBPUSU10K20H	12	450	400	150
GVSBPUSU20K60H	25	600	550	220
GVSBPUSU80K120H	40	800	600	280

Clearance

NOTE: Clearance dimensions are published for airflow and service access only. Consult with the local safety codes and standards for additional requirements in your local area.



Environment

	Operating	Storage
Temperature	0 °C to 40 °C	-25 °C to 55 °C
Relative humidity	0-95% non-condensing	0-95% non-condensing
Elevation	0-3000 m	
Protection class	IP20	
Color	RAL 9003, gloss level 85%	


One Line Diagrams

Galaxy VS One Line Diagrams


UIB	Unit input breaker
SSIB	Static switch input breaker
MBB	Maintenance bypass breaker
IMB	Internal maintenance breaker
UOB	Unit output breaker
SIB	System isolation breaker

NOTE: The internal maintenance breaker IMB* in the Galaxy VS UPS cannot be used in a system with an maintenance bypass panel and the internal maintenance breaker IMB* must be padlocked in the open position.


Galaxy VS – Single System – Single Mains




Galaxy VS – Single System – Dual Mains



Galaxy VS – Simplified 1+1 Parallel System – Single Mains



Galaxy VS – Simplified 1+1 Parallel System – Dual Mains




Easy UPS 3S and Easy UPS 3M One Line Diagrams


UIB	Unit input breaker
SSIB	Static switch input breaker
MBB	Maintenance bypass breaker
UOB	Unit output breaker

NOTE: The internal MBB in the Easy UPS 3S/3M cannot be used in a system with a parallel maintenance bypass panel and the internal MBB must be padlocked in the open position. Only use the Ext. MBB in the parallel maintenance bypass panel for maintenance bypass operation.

Easy UPS 3S and Easy UPS 3M – Single Mains




Easy UPS 3S and Easy UPS 3M – Dual Mains




Installation Procedure for Galaxy VS UPS


Single System – Single Mains




Single System – Dual Mains



Simplified 1+1 Parallel System – Single Mains



Simplified 1+1 Parallel System – Dual Mains




— Signal cable
 — Power cable

1. Mount the Maintenance Bypass Panel to the Wall, page 17.
2. Prepare the Maintenance Bypass Panel for Cables, page 19.
3. Only in countries where required: Remove the Neutral Jumpers, page 20.
4. Connect the Power Cables for a 3:3 UPS System, page 21.
5. Do one of the following:
 - Connect the Signal Cables for Galaxy VS UPS – Single System, page 26, or
 - Connect the Signal Cables for Galaxy VS UPS – Simplified 1+1 Parallel System, page 29.
6. Add Translated Safety Labels to Your Product, page 39.


7. Final Installation, page 40.

Installation Procedure for Easy UPS 3S and Easy UPS 3M

Single System – Single Mains



Single System – Dual Mains



— Signal cable
— Power cable

1. Mount the Maintenance Bypass Panel to the Wall, page 17.
2. Prepare the Maintenance Bypass Panel for Cables, page 19.
3. Remove the Neutral Jumpers, page 20.
4. Do one of the following:
 - **For 3:3 UPS system:** Connect the Power Cables for a 3:3 UPS System, page 21, or
 - **For 3:1 UPS system:** Connect the Power Cables for a 3:1 UPS System, page 24.
5. Connect the Signal Cables for Easy UPS 3S and Easy UPS 3M – Single System, page 36.
6. Add Translated Safety Labels to Your Product, page 39.
7. Final Installation, page 40.

Mount the Maintenance Bypass Panel to the Wall


⚠ CAUTION

RISK OF INJURY OR EQUIPMENT DAMAGE




- Mount the maintenance bypass panel to a wall or a rack that is structurally sound and able to support the weight of the unit.
- Use appropriate hardware for the wall/rack type.

Failure to follow these instructions can result in injury or equipment damage.

1. Remove the screws and open the inner door in the maintenance bypass panel.



2. Measure and mark the four mounting hole locations on the wall.

GVBPSU10K20H**GVBPSU20K60H****GVBPSU80K120H**

3. Drill holes in the four marked locations and mount the anchor bolts.
4. Mount the maintenance bypass panel to the wall.

Prepare the Maintenance Bypass Panel for Cables


⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Do not drill or punch holes with the gland plates installed and do not drill or punch holes in close proximity to the maintenance bypass panel.

Failure to follow these instructions will result in death or serious injury.

1. Remove the gland plate.



2. Drill or punch holes for cables or grommets in the gland plate.

⚠ DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Ensure that there are no sharp edges that can damage the cables.

Failure to follow these instructions will result in death or serious injury.

3. Install grommets (if applicable) and reinstall the gland plate.

Remove the Neutral Jumpers


NOTE: The neutral jumper makes a bolted connection of the neutral so that the neutral is not disconnected when the 4-pole breakers are opened.

NOTE: Only remove the neutral jumpers in a Galaxy VS installation, if this is a local requirement. Removal of the neutral jumpers is an **option** for a Galaxy VS installation.


NOTE: Always remove the neutral jumpers in an Easy UPS 3S installation or in an Easy UPS 3M installation. Removal of the neutral jumpers is **mandatory** for an Easy UPS 3S or an Easy UPS 3M installation.

1. Remove the neutral jumpers from the breakers.


GVSBPSU10K20H



GVSBPSU20K60H



GVSBPSU80K120H




Connect the Power Cables for a 3:3 UPS System


NOTE: For a simplified 1+1 parallel system, install the power cables from the two UPSs on the front and rear side of the busbar using the same bolt.

1. Connect the PE cables to the PE busbar.

GVCBPSU10K20H




GVCBPSU20K60H and GVCBPSU80K120H




2. Do one of the following:
 - **For single mains:** Connect the input cables from utility/mains.
 - **For dual mains:** Connect the bypass cables from utility/mains.
3. Do one of the following:
 - **For single mains:** Connect the UPS input cables.
 - **For dual mains:** Connect the UPS bypass cables.
4. Connect the UPS output cables.

5. Connect the load cables.

GVSbpsu10k20h



GVBPSU20K60H and GVBPSU80K120H




6. Fasten the cables with cable ties (provided) to the cable reliefs in the left side, top, and bottom of the maintenance bypass panel.

Connect the Power Cables for a 3:1 UPS System

1. Connect the PE cables to the PE busbar.


GVSBPSU20K60H and GVSBPSU80K120H



2. Do one of the following:
 - **For single mains:** Connect the input cables from utility/mains.
 - **For dual mains:** Connect the bypass cables from utility/mains (L1 and N only).
3. Do one of the following:
 - **For single mains:** Connect the UPS input cables.
 - **For dual mains:** Connect the UPS bypass cables (L1 and N only).
4. Connect the UPS output cables.

5. Connect the load cables.

GVSBPSU20K60H and GVSBPSU80K120H




6. Fasten the cables with cable ties (provided) to the cable reliefs in the left side, top, and bottom of the maintenance bypass panel.


Connect the Signal Cables for Galaxy VS UPS – Single System

NOTE: Route the signal cables separately from the power cables and route the Class 2/SELV cables separately from the non-Class 2/non-SELV cables.

GVSbpsu10k20h




GVSbpsu20k60h and GVSbpsu80k120h




1. Connect the Class 2/SELV signal cables for the breaker indicator lights from the control terminal block in the maintenance bypass panel to the UPS as per your configuration.

NOTE: The breaker indicator light circuit is considered Class 2/SELV. Class 2/SELV circuits must be isolated from the primary circuitry. Do not connect any circuit to the breaker indicator light terminals unless it can be confirmed that the circuit is Class 2/SELV.

Single System – Single Mains




Single System – Dual mains




2. Connect the non-Class 2/non-SELV signal cables from the control terminal block in the maintenance bypass panel to the UPS as per your configuration.

Single System – Single Mains



Single System – Dual Mains



3. Pull up the slack in the signal cables and fasten the signal cables to the cable reliefs.

Connect the Signal Cables for Galaxy VS UPS – Simplified 1+1 Parallel System


NOTE: The breaker indicator lights are supplied by UPS 1 and will only work while UPS 1 is powered.

NOTE: The AUX switches are in optional parallel installation kit GVSOPT006 provided with the UPS.


NOTE: Route the signal cables separately from the power cables and route the Class 2/SELV cables separately from the non-Class 2/non-SELV cables.

1. Install an AUX switch in the unit input breaker UIB/static switch input breaker SSIB and the maintenance bypass breaker MBB.
 - a. Remove the AUX switch cover on the UIB/SSIB and MBB breaker.
 - b. Install the AUX switch from kit GVSOPT006 in the UIB/SSIB and MBB breaker.
 - c. Connect the non-Class 2/non-SELV signal cables to the AUX switch in the UIB/SSIB and MBB breaker.
 - d. Reinstall the AUX switch cover on the UIB/SSIB and MBB breaker.
 - e. **Only for GVSBPSU80K120H:** Fasten the signal cables to the plastic tabs to ensure correct separation from the busbars.


GVSBPSU10K20H



GVSBPSU20K60H




GVSBPSU80K120H




2. Connect the Class 2/SELV signal cables for the breaker indicator lights from the control terminal block in the maintenance bypass panel to the UPSs as per your configuration.

NOTE: The breaker indicator light circuit is considered Class 2/SELV. Class 2/SELV circuits must be isolated from the primary circuitry. Do not connect any circuit to the breaker indicator light terminals unless it can be confirmed that the circuit is Class 2/SELV.

Simplified 1+1 Parallel System – Single Mains



Simplified 1+1 Parallel System – Dual mains



3. **On UPS 2:** Cut the preinstalled jumper between pins 8 and 9 on the terminal connector for J6618 on board 640-4864.

NOTICE


RISK OF INCORRECT EQUIPMENT BEHAVIOR

Cut the preinstalled jumper between pins 8 and 9 on terminal J6618 on board 640-4864 on UPS 2. The 24 V_SELV_OUT cannot be supplied from both UPSs.


Failure to follow these instructions can result in equipment damage.

- Connect the non-Class 2/non-SELV signal cables from the control terminal block in the maintenance bypass panel to the UPSs as per your configuration.


Simplified 1+1 Parallel System – Single Mains




Simplified 1+1 Parallel System – Dual Mains




GVSbpsu10k20h



GVSbpsu20k60h



GVSbpsu80k120h




5. Pull up the slack in the signal cables and fasten the signal cables to the cable reliefs.


Connect the Signal Cables for Easy UPS 3S and Easy UPS 3M – Single System

1. Remove the three breaker indicator lights and the breaker indicator light labels from the maintenance bypass panel. The breaker indicator lights are not supported with the Easy UPS 3S and the Easy UPS 3M.

GVSBPSU20K60H and GVSBPSU80K120H




2. Install three round blanking plugs (not provided) in the holes in the inner door.
3. On the control terminal block, remove the internal connections for the breaker indicator lights (pin 1-4).
4. On the control terminal block, modify the internal connection for the MBB AUX switch (pin 7-8) from Normally Closed (NC) to Normally Open (NO).



5. Connect the Class 2/SELV signal cables from the control terminal block in the maintenance bypass panel to the UPS as per your configuration.


NOTE: Route the signal cables separately from the power cables and route the Class 2/SELV cables separately from the non-Class 2/non-SELV cables.

GVSBPSU20K60H and GVSBPSU80K120H




NOTE: There is no dedicated input contact on Easy UPS 3S for MBB. By default use J5 configurable input contact, configure as **Main CB NO.**

Easy UPS 3S



Easy UPS 3M



6. Pull up the slack in the signal cables and fasten the signal cables to the cable reliefs.

Add Translated Safety Labels to Your Product


The safety labels on your product are in English and French. Sheets with translated safety labels are provided with your product.

1. Find the sheets with translated safety labels provided with your product.
2. Check which 885-XXX numbers are on the sheet with translated safety labels.
3. Locate the safety labels on your product that match the translated safety labels on the sheet – look for the 885-XXX numbers.
4. Add the replacement safety label in your preferred language to your product on top of the existing French safety label.


Final Installation

1. Close the inner door and fasten it with the screws.
2. Add labels to the breaker indicator lamps, the breakers, and the diagram label according to your system. The labels are provided with this manual.


Labels in Single System – Single Mains




Labels in Single System – Dual Mains



Labels in Simplified 1+1 Parallel System – Single Mains



Labels in Simplified 1+1 Parallel System – Dual Mains



Schneider Electric
35 rue Joseph Monier
92500 Rueil Malmaison
France

+ 33 (0) 1 41 29 70 00



As standards, specifications, and design change from time to time,
please ask for confirmation of the information given in this publication.

© 2018 – 2022 Schneider Electric. All rights reserved.

990-5912C-001