

UK Declaration of Conformity

UK1007025-0

1.0 Product Identification



Object of the declaration: Rogowski Coil Current Transducers
 Product: CTRx Series
 Reference: Refer to Annex

2.0 This declaration of conformity is issued under the sole responsibility of the manufacturer.

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison, FRANCE

3.0 We Undersigned Schneider Electric Industries SAS declare that Schneider Electric branded products, when subject to correct installation, Maintenance and use confirming their intended purpose, according to applicable regulations and standards in the country where they are installed, to the supplier’s instructions and to accepted rules of the art comply with essential requirements of following Statutory Inventories and is also in conformity with the relevant union harmonization legislation.

4.0

Statutory Inventory with Amendments	Harmonized Standards/Other Technical Specification
SI 2012 No. 3032+ SI 2019 No. 492 - The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations	BS EN IEC 63000:2018
SI 2016 No. 1101 - The Electrical Equipment (Safety) Regulations	BS EN 61010-1:2010+A1:2019

5.0 Signed for on behalf of:
 Place and Date:
 Signature:

Schneider Electric Industries SAS
 Telford, UK, 30.09.2025

Name / Title:

Signed by:

A578D60923D7459...
David Williams
 VP Marketing UK & Ireland

UK Declaration of Conformity

UK1007025-0

Annex

Product	Short Description
METSECTR25500U	CT Rogowski 250 mm (9.8 in) coil, 1000 A, Lead length 2.4 m (8 ft)
METSECTR30500U	CT Rogowski 300 mm (11.8 in) coil, 2000 A, Lead length 2.4 m (8 ft)
METSECTR46500U	CT Rogowski 460 mm (18.1 in) coil 5000 A, Lead length 2.4 m (8 ft)
METSECTR60500U	CT Rogowski 600 mm (23.6 in) coil 5000 A, Lead length 2.4 m (8 ft)
METSECTR90500U	CT Rogowski 900 mm (35.4 in) coil 5000 A, Lead length 2.4 m (8 ft)