



# Certificate

**Customer:** **Assmann Electronic GmbH**  
Auf dem Schüffel 3  
D-58513 Lüdenscheid, Germany

**Description:** **Assmann Patchcord Cat5e SF-UTP**  
**Part-No.: DK-1531-XX**

**Applied standards:** TIA/EIA-568-B.2: 2002  
Transmission Performance Specifications for 4-Pair 100Ω Category 5e Cabling  
ISO/IEC 11801: 2002-09  
Information technology – Generic cabling for customer premises  
EN 50173-1: 2002  
Information technology – Generic cabling systems Part 1  
  
Draft IEC 61935-2: 2004  
Generic cabling systems – Specification for the testing of balanced communication cabling in accordance with EN 50173 – Part 2: Patch cords and work area cords

**Comments:** The sample, a **Patchcord**, meets the **Cat. 5e (100MHz)** limits of the specified standards and regulations.

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the data cables or connectors are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, **no. P1917a-08-E, from July 29<sup>th</sup> 2008** and shall only be applicable in conjunction with the test report.

Bexbach, July 29<sup>th</sup> 2008

Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



GHMT AG  
In der Kolling 13  
D-66450 Bexbach  
Phone: +49 (0) 68 26 / 92 28 – 0  
Fax: +49 (0) 68 26 / 92 28 – 99  
E-Mail: [info@ghmt.de](mailto:info@ghmt.de)  
<http://www.ghmt.de>