

PRODUCT-DETAILS

JRA/S 4.24.5.1

JRA/S4.24.5.1 Blind/Roller Shutter Act, Travel Det, 4-f, 24 V DC, Man Op, MDRC



Informations générales

Extension du type de produit	JRA/S 4.24.5.1
Code de produit	2CDG110128R0011
EAN	4016779698474
Description courte	JRA/S4.24.5.1 Blind/Roller Shutter Act, Travel Det, 4-f, 24 V DC, Man Op, MDRC
Description longue	For the control of up to 4 independent 24 V DC drives via ABB i-bus® KNX. The device is designed for positioning blinds, roller shutters, awnings and other shading products as well as for controlling doors, windows and ventilation flaps. Additional auxiliary voltage is not needed. The travel times of the drive are detected automatically via current detection. Push buttons are located at the front of the device to control the outputs e.g. during commissioning. The current status of the output is displayed via LEDs.

Installation

Instructions et manuels	2CDG941079P0005
-------------------------	-----------------

Technique

Fiche produit, informations techniques	2CDC506040D0201 2CDC506064D0202
Type de courant	DC

Fonctions spéciales	Switching
Voltage Range	24 V
Tension de sortie (U_{out})	24 V DC
Maximum Switching Current	6 A
Maximum Switching Power	2400 W
Power Loss	0.25 W
Nombre de sorties	4
Nombre de LED	1
Compatible Bus Systems	KNX (TP)
Product Range	KNX
Type de montage	DIN-Rail
Manual Operation	Oui
Couleur	light grey
Nombre de batteries	0
Application Function	Blind / Shutter / Shading Control

Environnement

Indice de protection	IP20
Statut RoHS	Following EU Directive 2002/95/EC August 18, 2005 and amendment
Informations RoHS	2CDG510125-0100
REACH Declaration	9AKK107492A1906
Conflict Minerals Reporting Template (CMRT)	9AKK108468A3363

Dimensions

Width in Number of Modular Spacings	4
Produit Largeur Net	72 mm
Produit Hauteur Net	90 mm
Produit Longueur Net	64.5 mm
Poids net	0.22 kg
Profondeur d'encastrement (t_2)	64.5 mm
Schéma dimensionnel	2CDC072033F0015

Certificats et Déclarations (Numéro de document)

CB Certificate	9AKK107991A3191
Déclaration de Conformité - CE	2CDK506043D2701
KNX Certificate	9AKK105710A0051

Classifications

ETIM 8	EC001330 - Shutting actuator for bus system
ETIM 9	EC001330 - Shutting actuator for bus system
Catégorie DEEE	5. Small Equipment (No External Dimension More Than 50 cm)
WEEE B2C / B2B	Business To Consumer
CN8	8537 10 91
eClass	V11.0 : 27143128
Code de classification d'objet	A

Accessories

Identifiant	Description	Type	Quantity	Unit Of Measure
GHQ6310084R0111	JSB/S1.1 Shutter Control Unit, MDRC	JSB/S 1.1	1	piece

Catégories

Produits basse tension → Home and Building Automation → KNX → Shading Control → Blind Actuators 24 V DC



360