
# SBLT800 / SBTT800 561146/561147


1000V AC/DC Short-Circuit Current Rating † 100 kA @ 600V

IEC<sup>®</sup> 60947-7-1 Ui: 1000V AC / 1500V DC Uimp: 12 kV Icw: 57.6 kA rms 1s\*


561146: SBLT800

IEC: 1250 AMP / UL: 760 AMP / CSA: 760 AMP





IEC: 1250 AMP / UL: 760 AMP / CSA: 760 AMP



Ø	UL IEC	IEC only	QTY	STRIP LENGTH	ರ
.866 in	3/0500 AWG	-	X2	1.2 in	300 in-lbs
22.0 mm	95240mm²	50185mm²		30.0 mm	34 N-m

- NOTES:

  \* For IEC Short-Circuit applications the cable must be secured within 20cm of the terminal block

  † See UL file E198301 for UL1059SA Short-Circuit current rating conditions

  ‡ Conductors used in parallel must be of same size and type

  # Torque screws of unused galleries to 2.0 Nm (18 in.lbs)

- IEC current produced a temperature rise of less than 45K when used with appropriate and adequate cable(s)

- RNING:

  Nent products shall be installed and used only as indicated in nVent product instruction sheets and training materials. Instruction sheets are available at <a href="https://www.nVent.com">www.nVent.com</a> and from your nVent customer service representative.

  NVent products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings. All instructions must be completely followed to ensure proper and safe installation and performance.

  Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property demands a critical backly inclined and load deather and valid our warrants. damage, serious bodily injury and/or death, and void your warranty.

1 OF 2

All governing codes and regulations and those required by the job site must be observed.


Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.


nVent, CADDY, ERICO CADWELD, ERICO CRITEC, ERICO, ERIFLEX, and LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.







# SBLT800 / SBTT800 561146/561147





## Easy Side-by-Side attachment






installation and removal - Must be pushed in when installed on DIN profile

### NOTE:

For multiple phase assemblies, join blocks together before installing on DIN profile When mounted on DIN profile end stops must be used on both ends of a set of blocks.

### **ACCESSORIES**

**561138: SBLEC - END STOP** 



nVent, CADDY, ERICO CADWELD, ERICO CRITEC, ERICO, ERIFLEX, and LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.



