
## **SBF250** 561171



IEC 60947-7-1										
	No. Terminals	Conductor	Size	Ø DIA	Torque	Strip Length	Hex			
	1	ERIFLEX FLEXIBAR [ERIFLEX IBSB]	2X20X1 to 5X20X1 [50 to 70 mm²] Hole size 8.5mm	N/A	- 31.1 N-m	29.2 mm	- 8 mm			
	1		35 mm² to 120 mm²	15.1 mm		27.4 mm				

The IBSB conductor must be pushed as far as possible into the housing

UL 1953 (must use SB250SPCR to comply)												
	No. Terminals	Conductor	Size	Ø DIA	Torque	Strip Length	Hex					
	1	ERIFLEX FLEXIBAR [ERIFLEX IBSB]	2X20X1 to 5X20X1 [50 to 70 mm²] Hole size 8.5mm	N/A	275 in-lbs	1.15 in	5/16 in					
	1	High Strand, DLO*	6 AWG to 250 kcmil	0.594		1.08						

SBF250 is UL 1059 Recognized when used without SB250SPCR. Voltage rating for UL 1059 applications is 1250 V AC/DC.

## NOTE:

- \*Refer to UL file E198301 for conditions of acceptance.
- 2. For multiple phase assemblies, join blocks together before installing DIN profile.
- When mounted on DIN profile, end stops should be used on both ends of gangable blocks.
- For IEC, the cable must be secured within 15cm of the terminal.

## WARNING:

- KNINC:
  n Vent products shall be installed and used only as indicated in nVent product instruction sheets and training materials. Instruction sheets are available at <a href="https://www.nVent.com">www.nVent.com</a> and from your nVent customer service representative.

  nVent products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings. All instructions must be <a href="https://completely-followed-to-ensure-proper-and-safe-installation">completely-followed-to-ensure-proper-and-safe-installation</a> and performance.

  Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, properly damage, serious bodily injury and/or death, and void your warranty.

1 OF 1

SAFETY INSTRUCTIONS:
All governing codes and regulations and those required by the job site must be observed.
Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.

nVent, nVent CADDY, nVent ERICO, nVent GARDNER BENDER, nVent ILSCO, nVent KING INNOVATION, and nVent LENTON are owned by nVent or its global affiliates. All other trademarks are the property of their respective owners. nVent reserves the right to change specifications without prior notice.



