MFVN0400EG

MFVN0450EG

MFVN0500EG

MFVN Macro-V Non-Insulated M8/M10 For 100 - 500 mm duct sizes

400

450


500

Wrench size Socket **Tightening** Duct Article **Product** Part Number **Rod Size** for M8/M10 torque for Size size for Number **Load Rating** Nut M6 screw (mm) M6 screw MFVN0100EG 586503 100 MFVN0125EG 586505 125 MFVN0140EG 586506 140 586507 150 775 N * MFVN0150EG 586508 160 MFVN0160EG MFVN0180EG 586509 180 200 MFVN0200EG 586510 M8/M10 13 mm 10 mm 2 Nm MFVN0224EG 586511 224 MFVN0250EG 586512 250 MFVN0315EG 586515 315 1,000 N * MFVN0355EG 586516 355

586517

586518

586519



WARNING

- RNING:

 nVent products shall be installed and used only as indicated in nVent product instruction sheets and training materials. Instruction sheets are available at
 www.nvent.com and from your nVent customer service representative.

 nVent products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings.

 All instructions must be completely followed to ensure proper and safe installation and performance.

 Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and/or death, and void your warranty.

 Products that are manufactured using spring steel components shall be used only in a non-corrosive indoor environment.

 All pipe supports, hangers, intermediate components and structural attachments must ONLY be used as described herein and are NEVER to be used for any other purpose.

NOTE: All load ratings are for static conditions and do not account for dynamic loading such as wind, water or seismic loads, unless otherwise noted.

The customer is responsible for:

a. Conformance to all governing codes.
b. The integrity of structures to which the products are attached, including their capability of safely accepting the loads imposed, as evaluated by a qualified

engineer.

c. Using appropriate industry standard hardware as noted above.

All governing codes and regulations and those required by the job site must be observed.


Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.





900 N

^{*} RAL CERTIFIED PRODUCT LOAD RATING PER RAL-GZ 655.








CFS563_E

MFVN Macro-V Non-Insulated M8/M10 For 630 - 1000 mm Duct Sizes

Part Number	Article Number	Duct Size (mm)	Rod Size	Wrench size for M8/M10 Nut	Socket size for M6 screw	Tightening torque for M6 screw	Product Load Rating
MFVN0630EG	586522	630	M10/M8	13 mm	10 mm	2 Nm	1,150 N
MFVN0800EG	586524	800					
MFVN1000EG	586526	1000					1,400 N



- RNING:

 Nent products shall be installed and used only as indicated in nVent product instruction sheets and training materials. Instruction sheets are available at www.nVent.com and from your nVent customer service representative.

 NVent products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings.

 All instructions must be completely followed to ensure proper and safe installation and performance.

 Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, properly damage, serious bodily injury and/or death, and void your warranty.

 Products that are manufactured using spring steel components shall be used only in a non-corrosive indoor environment.

 All pipe supports, hangers, intermediate components and structural attachments must ONLY be used as described herein and are NEVER to be used for any other purpose.

NOTE: All load ratings are for static conditions and do not account for dynamic loading such as wind, water or seismic loads, unless otherwise noted.

The customer is responsible for:

- a. Conformance to all governing codes.
 b. The integrity of structures to which the products are attached, including their capability of safely accepting the loads imposed, as evaluated by a qualified
- engineer.

 c. Using appropriate industry standard hardware as noted above.

SAFETY INSTRUCTIONS:
All governing codes and regulations and those required by the job site must be observed.
Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.





