



**CONNECT AND PROTECT**

nVent ERICO Isolated  
Downconductors ISOv  
Lightning Protection Systems

  
nVent  
ERICO

# The Importance of Protecting Rooftop Equipment




Today's building rooftops are valuable real estate and have become home to an increasingly complex array of electrical equipment such as mobile telephone system antennas, digital transmission equipment and HVAC systems. rooftops are also vulnerable to lightning strikes and that equipment can easily be damaged.

Traditionally, structures have been protected by the use of air terminals placed on the actual structure, with an emphasis on protecting the building itself from the damaging effects of the lightning strike. These air terminals served to intercept the strike with downconductors, safely conveying the energy to the earth termination system. These systems have been used for more than a century. In more recent times, methods, such as those described in the IEC 62305 series of lightning protection standards, have specified the placement of the air terminals and the downconductors together with details of the earth termination system. Items of metal on the rooftop, like flagpoles, handrails and plumbing are usually bonded (connected) to the lightning protection system.

However, contemporary buildings often have much sensitive electrical equipment mounted on the exposed rooftop. The traditional building lightning protection techniques are not well suited to protect such modern rooftop devices. With the possibilities of large currents that can be conducted by the lightning protection system, the close proximity of this electrical and electronic equipment is of paramount concern. That is, when the equipment is unavoidably close to the lightning conductors, the traditional practice is to bond the equipment frames, masts and cable sheaths to the lightning protection system. These now form part of the lightning discharge path, and damage to the equipment can result.

The IEC Lightning Protection Standards provide two approaches to lightning protection, the traditional bonding of metallic items in order to minimize

potential differences, or the use of an isolated system where the lightning protection system is insulated from the structure and equipment. One method of constructing an isolated system is to use insulated brackets and fixings to hold the air terminals, and downconductors at some distance away (typically from 300 mm to 1000 mm) from the equipment and structure. Despite being a technically correct approach, the appearance, complexity, susceptibility to damage and cost limit its use. In some applications, when protecting smaller structures, a completely separate and taller mast is built adjacent to the structure. An air termination on the taller mast can provide coverage over the smaller structure, whereas the downconductor runs down the mast, physically away from the structure and its contents. This is often not practicable, especially for the telecommunication industry in which mounting a second taller mast for the protection of the first one is not a realistic solution.



Simple lightning protection system before the proliferation of rooftop equipment

# The Importance of Protecting Rooftop Equipment



# The nVent ERICO Isolated Downconductors (ISOOnV) System


To be protected from the damaging effects of lightning, rooftop equipment has to, firstly, be within the protective area of an elevated air terminal to avoid being directly struck by lightning. Secondly, it must be sufficiently far enough away from the lightning protection system (LPS) conductors connecting those air terminals, including being far enough away from any metallic objects deliberately, or unavoidably, connected to the LPS, to avoid lightning flashing over from the LPS to the equipment.

The IEC lightning protection system calls that “sufficiently far enough away” distance the Separation Distance, and has a calculation method to determine the separation distance required at all points on the lightning protection system. If the equipment is closer than the separation distance, it must be bonded to the LPS. That might seem strange, but if it weren’t connected, lightning would flash over anyway, potentially causing even more damage. Either way, bonded or unbonded, there is the potential for damage to the equipment.

Is there a way of avoiding a lightning flash over to the equipment when it is unavoidably too close to an LPS conductor without having to bond it and without having the resulting damage possibility?

The ISOOnV system is designed as a solution to this problem. At the heart of this system is the use of LPS conductors that are constructed with a high performance insulation to prevent electrical breakdowns (flashovers) even with the high voltages from a lightning strike. Since their development, nVent ERICO insulated downconductors, with their pioneering use of a semi-conductive sheath, have proven their reliability on tens of thousands of structures over several decades.

The ISOOnV conductors have been specifically designed and tested to IEC TS 62561-8 for use with an isolated LPS as described in the IEC 62305 series of Lightning Protection Standards.



# The ISOOnV System



The performance of the insulation is tested in a laboratory to IEC TS 62561-8, with the result being expressed as the conductor having an "equivalent separation distance" to that provided by that distance of air. The ISOOnV conductors have this equivalence as follows:

ISOOnV Conductor	Equivalent Separation Distance in Air
ISONV50	50 cm (0.50 m)
ISONV70	70 cm (0.70 m)

High voltages can cause tracking along object surfaces and cause breakdowns through solid objects such as walls, more easily than sparking through the air, so the IEC 62305-3 standard says that the separation distance along surfaces or through brick, concrete, or wooden walls should be double that needed for a breakdown through air.



Upper termination of ISOOnV conductor


Lower termination of ISOOnV conductor provides a 10 mm stud

# The ISOOnV System



Since the ISOOnV conductors are designed to connect to air terminals, the separation distance concept needs to be applied around the air terminal. The ISOOnV system includes special masts that feature an insulating support structure. The overall system LPS design determines the size of the air terminals required and the mast heights. How the masts are mounted depends on the structure, but freestanding masts with concrete blocks, and various mounting bracket arrangements are available.

The mast stands feature an easy procedure that allow the mast to be readily positioned in place with the air terminal and conductors, saving time and complexity on the job site.




# The ISOOnV System

In addition, more comprehensive ISOOnV isolated system designs require that multiple ISOOnV conductors connect to the air terminal on a single mast, and the system accommodates that too. The conductor within the mast


is always used, and up to four additional conductors can be mounted down the outside of the supporting mast. A comprehensive installation manual gives more details on the aspects of these installation variants.




Up to four conductors can be added around the outside of the mast, in addition to the conductor that must always be present inside the mast.




A number of fastening solutions are available to fasten the conductor as per the requirements of the standard




ISONVSEAM




ISONVTILE



ISONVCORR



ISONVSTRAPFS



ISONVBLOCK4KG

# Your Partner for Innovative Lighting Protection Solutions

## THE SIX POINT PLAN OF PROTECTION

### **1 Capture the lightning strike.**

Capture the lightning strike to a known and preferred attachment point using a purpose-designed air terminal system.

### **2 Convey this energy to ground.**

Conduct the energy to the ground via a purpose-designed downconductor.

### **3 Dissipate energy into the grounding system.**

Dissipate energy into a low impedance grounding system.

### **4 Bond all ground points together.**

Bond all ground points to eliminate ground loops and create an equipotential plane.

### **5 Protect incoming AC power feeders.**

Protect equipment from surges and transients on incoming power lines to prevent equipment damage and costly operational downtime.

### **6 Protect low voltage data/telecommunications circuits.**

Protect equipment from surges and transients on incoming telecommunications and signal lines to prevent equipment damage and costly operational downtime.


For decades, nVent ERICO has been a global leader in lightning protection. In the 1980s, when we developed a six point plan for the coordinated protection of a facility from lightning damage, our integrated systems have been used to protect many thousands of critical facilities around the globe. The six point plan recognized the importance of combining external direct strike lightning protection and internal surge protection with a good equipotentially bonded earthing system to maximize the protection achieved.

A critical part of the plan was recognizing the role that insulated downconductors play in protecting equipment from damage. Unlike non-insulated conductors, using insulated conductors allows complete control of where the damaging lightning current flows. Our dedicated application engineers help our customers design these systems, and today there are now some tens of thousands of installed systems worldwide using nVent insulated lightning conductors.

# Your Partner for Innovative Lighting Protection Solutions

## DID YOU KNOW?

While the ISOOnV product family excels at providing a cost effective solution for many difficult lightning protection problems, the nVent ERICO System 3000 lightning protection system features the nVent ERICO Ericore coaxial insulated lightning downconductor that is able to achieve single conductor lengths in excess of 70 to 80 m.



## NVENT INVOLVEMENT IN LIGHTNING PROTECTION RESEARCH



nVent has investigated the lightning protection process through years of research involving long term field studies. Laboratory testing, using some of the largest outdoor test laboratories, and countless research study programs, including joint ventures with accomplished scientists in the field have also been used in the research process. This extensive research has resulted in some of the most up-to-date published technical papers and journals. nVent is committed to the development of a range of lightning protection standards around the world.

# ISOv System Design

## LPS DESIGN STEPS:

### Step 1

An LPS design using the ISOv system begins by ensuring the coverage of the rooftop equipment and the building that will be protected, by using the Protection Angle Method, the Rolling Sphere Method or both methods. The ISOv system inherently uses masts and longer rods, enabling greater protective areas with fewer rods, compared with traditional methods using shorter rods without masts. This design aspect is similar to both an isolated and non-isolated system with a difference being that the design of the isolated system uses only dedicated air terminations rather than including natural elements of the building to ensure the LPS isolation in the area where isolation is required.

### Step 2

Having completed the LPS design as far as the position of the air terminals and conductors to ensure correct coverage, the "separation distance" calculation is executed. For this exercise, a computer simulation software is often used.

IEC Lightning Protection Standards' formula:

$$s = k_i \frac{k_c}{k_m} I$$

IEC 62305-3 Ed.2.0 Section 6.3, equation 4

**Where:**

$k_i$  depends upon the selected class of LPS

$k_c$  depends upon the lightning current flowing on the downconductors ( $k_c = 1$  for a single downconductor)

$k_m$  depends upon the electrical insulation material ( $k_m = 1$  for air, or 0.5 for concrete, bricks, and wood)


$I$  is the length, in meters, along the downconductor (from nearest equipotential bonding point, i.e. normally from lower termination), to the point where the separation distance is being considered.

Class of LPS (LPL Lightning Protection Level)	$k_i$
I	0.08
II	0.06
III	0.04
IV	0.04

The factor,  $k_c$ , can be difficult to calculate, but where the proposed insulated conductor is just a single length going from the air terminal to the nearest equipotential bonding point (a single downconductor),  $k_c = 1$ , and the maximum length allowable for the ISOv conductors is as follows:


Conductor	Class of LPS		
	I	II	III and IV
ISOv50	6.3 m	9.4 m	12.5 m
ISOv70	8.8 m	13.1 m	17.5 m

Maximum conductor length for individual non-interconnected conductors



# ISONV System Design

These maximum lengths would apply in the following examples:




The illustration on the left shows a conductive building and roof. The base of the antenna mast, where the insulated conductor connects, is an equipotential bonding point. The conductor length is 8 m, so that for a Class I LPS, ISONV70 conductor must be used, but for a Class II to IV LPS, ISONV50 could be used.


The illustration on the right shows an insulated conductor that goes all the way to the earth termination network. Since the total insulated conductor length is only 6 m, ISONV50 conductor could be used for any Class of LPS.

Adding a second insulated conductor to the same air terminal mast allows the maximum lengths to be doubled.

In the following example, 9 masts are installed to provide an isolated LPS over the complete rooftop and building. The building has a height of 10 m, and has a width and length of 30 m.



# ISOv System Design



Allowing for the heights of the air terminations, computational software calculated the separation distances for the corner, edge, and center air terminations to be as follows.

Air Termination	Class of LPS		
	I	II	III and IV
Corners	0.56 m	0.42 m	0.28 m
Edges	0.48 m	0.36 m	0.24 m
Centre	0.60 m	0.45 m	0.30 m

Separation distances required at each Class of LPL

Depending on the Class of the LPS, the appropriate ISOv conductor can be chosen. This is an example where the simple single downconductor method of calculating the separation distance does not apply, since the lightning current splits between the network of interconnected conductors, and the factor,  $k_c$ , is difficult to calculate manually at each air terminal. nVent is able to offer design assistance with these more complex designs.


# ISOOnV System Design

## Step 3

Having verified that the separation distances are within that possible with the ISOOnV conductors, the Bill of Material is completed. More detailed information for that can be found in the installation manual for the system, which contains a part selection guide. If the separation distances required exceed the ISOOnV70 conductor, the design can be modified to shorten conductor lengths, or to add more air terminals and interconnecting conductors to split, and hence lower, the currents further.



# Testing




Test method for determining the Equivalent Separation Distance



Laboratory testing to verify the 200kA 10/350us rating for the cable with connectors and fasteners

The standard requires other tests, including a high current impulse test sequence. The ISOv conductors passed this test at the maximum value of 200kA 10/350us.

Our extensive experience in the industry pioneering innovative solutions, verified through scientific investigation and laboratory testing, demonstrates our skills and knowledge to solve your lightning protection problems. We have a proud history of working with lightning protection installation companies around the world, many of whom have worked with us for more than 30 years.



In 2018, the first edition of the IEC TS 62561-8 specification was released, and it provides a standardized way to test the electrical performance of insulated lightning conductors intended to help system designers overcome separation distance challenges.

nVent has had the ISOv system tested in independent test laboratories. The primary tests involve verification of the claimed equivalent separation distances. The conductor itself and the installation arrangements are tested. The method involves applying the same high voltage impulse to both the conductor under test and to a comparison air gap. A successful test result occurs when the air gap breaks down rather than the conductor insulation failing.



Laboratory testing to verify Equivalent Separation Distance including cable and freestanding mast

# ISOv System Parts

## ISOv INSULATED CONDUCTOR



- Provides protection of equipment against lightning strike flashover by providing an insulated path to ground via an equivalent separation distance

Part Number	Equivalent Separation Distance	Material
ISONV50	50 cm	Copper, Polyethylene
ISONV70	70 cm	

## ISOv CONDUCTOR CLAMP FOR SEAMED METAL ROOF



- Secures conductors to standing seam profiles
- Suits both ISOv50 and ISOv70

Part Number	Material
ISONVSEAM10	Stainless Steel 304 (conductor clamp), Galvanized Steel (seam clamp)

## ISOv CONDUCTOR CLAMP FOR INTERLOCKING ROOF TILE



- Secures ISOv Insulated Conductor to roof tiles
- Suits both ISOv50 and ISOv70

Part Number	Material
ISONVTILE	Stainless Steel 304

## ISOv CONDUCTOR CLAMP FOR CORRUGATED ROOF



- Secures ISOv Insulated Conductor to corrugated metal roofs

Part Number	Material
ISONVCORR10	Stainless Steel 304

## ISOv CONDUCTOR FASTENER



- Secures lightning protection conductors and prevents displacement

Part Number	Material
ISONVFS	Stainless Steel 304

## ISOv CONDUCTOR SUPPORT BLOCK



- Weighted ballast with cable fastener to support ISOv Insulated Conductor along rooftop
- Suits both ISOv50 and ISOv70

Part Number	Unit Weight	Material
ISONVBLOCK4KG	4 kg	Concrete (block), Stainless Steel 304 (conductor clamp)

## ISOv CONDUCTOR STRAP BRACKET



- Secures conductors to round objects such as masts, pipes and columns
- Suits both ISOv50 and ISOv70
- Use in conjunction with ISOvSTRAP and ISOvSTRAPC

Part Number	Material
ISONVSTRAPFS	Stainless Steel 304

# ISOv System Parts

## ISOv UPPER TERMINATION KIT, INSIDE MAST



- Kit includes upper termination, heat shrink tubing, hex key wrench, air terminal washers and crimp ring terminal for bonding to mast

Part Number	Conductor Type	Material
ISOTMN50KITU	ISONV50	
ISOTMN70KITU	ISONV70	316L

## ISOv UPPER TERMINATION KIT, OUTSIDE MAST



- Kit includes upper termination, heat shrink tubing, hex key wrench, air terminal washers, multi-cable adapter and an equipotential bond

Part Number	Conductor Type	Material
ISOTMN50KITUA	ISONV50	
ISOTMN70KITUA	ISONV70	316L

## ISOv LOWER TERMINATION KIT



- Kit includes lower termination, heat shrink tubing, and a hex key wrench

Part Number	Conductor Type	Material
ISOTMN50KITL	ISONV50	
ISOTMN70KITL	ISONV70	316L

## ISOv EQUIPOTENTIAL BOND KIT



- Used with ISOv lower terminations when equipotential bonding is required

Part Number	Conductor Type	Material
ISONVEBL50	ISONV50	Stainless Steel 304 (Conductor Bond), Tinned Copper (Terminal)
ISONVEBL70	ISONV70	

## MULTI-PURPOSE GROUNDING CLAMP, STAINLESS STEEL



- Convenient multi-purpose clamp designed to accommodate round conductors, flat conductors, ground rods and rebar

Part Number	Earth Rod	Material
MPSC404SS	14.2–19.0 mm Diameter, Actual (Ø)	Stainless Steel 304

## MULTI-PURPOSE GROUNDING CLAMP, STAINLESS STEEL



- Cross connector for round-to-round, round-to-tape, and tape-to-tape connections

Part Number	Conductor Size	Material
MPSC404SSA	8 mm Solid-10 mm Solid, 35 mm <sup>2</sup> Stranded-50 mm <sup>2</sup> Stranded 40 mm x 4 mm max. Tape	Stainless Steel 304

## ISOv STRAP CLAMP



- Fastens ISOv Strap
- Use in conjunction with ISOvSTRAP and either ISOvSTRAPBKT or ISOvSTRAPFS

Part Number	Material
ISONVSTRAPC	Stainless Steel 304

## ISOv STRAP



- Provides variable fastening on poles, masts and pipes
- Use in conjunction with ISOvSTRAPC and either ISOvSTRAPBKT or ISOvSTRAPFS

Part Number	Length	Material
ISONVSTRAP	50 m	Stainless Steel 304

# ISOOnV System Parts

## ISONV STRIPPING TOOL HANDLE



- For use with ISOOnV Stripping Tool Bushings to provide precise strip length of ISOOnV Insulated Conductor

Part Number	Material
ISONVSTRIP	Thermoplastic, Steel and Brass

## ISONV STRIPPING TOOL BUSHING



- For use with ISOOnV Stripping Tool Handle to provide precise strip length of ISOOnV Insulated Conductor

Part Number	Conductor Type	Material
ISONVSTRIP50	ISONV50	Thermoplastic,
ISONVSTRIP70	ISONV70	Stainless Steel Blades

## ISONV STRIPPING TOOL CARRYING CASE



- Designed to carry ISOOnV stripping tool handle, bushing and replacement blades

Part Number	Material
ISONVSTRIPCS	Polyethylene

## ISONV STRIPPING TOOL REPLACEMENT BLADE

- Replacement blades for ISOOnV Stripping Tool Bushing

Part Number	Material
ISONVSTRIPBL	Stainless Steel

## ISONV AIR TERMINAL



- Lightning strike termination points for use with air terminal bases

Part Number	Height	Material
LPAAT0500	500 mm	Aluminum
LPAAT1000	1,000 mm	
LPAAT1500	1,500 mm	
LPAAT2000	2,000 mm	
LPSAT1000	1,000 mm	Stainless Steel 304
LPSAT2000	2,000 mm	

## ISONV LOWER MAST



- For use with ISOOnV Upper Mast Assembly in vertical cantilever installations

Part Number	Material
ISONVMAST11	Aluminum
ISONVMAST24	
ISONVMAST37	

## ISONV LOWER MAST WITH OUTLET



- For use with ISOOnV Upper Mast Assembly in mast stand installations

Part Number	Material
ISONVMASTA11	Aluminum
ISONVMASTA24	
ISONVMASTA37	

# ISOv System Parts

## ISOv UPPER MAST ASSEMBLY



- For use with ISOv lower masts

### Part Number      Material

ISOMASTASSY	Polypropylene (cap), Fiberglass (mast), Stainless Steel 304 (coupler)
-------------	---

## ISOv MAST STAND



- Used to support ISOv mast assemblies with an outlet

### Part Number      Material

ISONVSTAND10	
ISONVSTAND15	Stainless Steel 304
ISONVSTAND25	

## ISOv ADJUSTABLE OFFSET MAST BRACKET



- Telescoping mast support for mounting under roof overhang

### Part Number      Offset Distance      Material

ISONVBKTXL	800 – 1,000 mm	Stainless Steel 304
------------	----------------	---------------------

## ISOv FIXED OFFSET MAST BRACKET



- Use for cantilevered mounting ISOv masts

### Part Number      Offset distance      Material

ISONVBKT15	15 mm	
ISONVBKT80	80mm	Stainless Steel 304
ISONVBKT200	200 mm	

## ISOv SQUARE RAILING MAST BRACKET



- Secures masts to square railing

### Part Number      Rail Size      Material

ISONVBKT50X50	50 mm x 50 mm	Stainless Steel 304
---------------	---------------	---------------------

## ISOv MAST TO PIPE BRACKET



- For mast-to-mast or pipe-to-mast mounting connections

### Part Number      Pipe Outside Diameter      Material

ISONVBKTR40	40 – 50 mm	
ISONVBKTR50	50 – 60 mm	Stainless Steel 304
ISONVBKTR70	70 – 80 mm	

## ISOv MAST STRAP BRACKET



- Secures masts to round objects such as masts, pipes and columns

### Part Number      Material

ISONVSTRAPBKT	Stainless Steel 304
---------------	---------------------

# ISOnV System Parts

## THREADED ROD EXTENSION



- Used with concrete block supports for inclined surfaces for level installation of mast stands

Part Number	Material
ISONVROD200EXT	
ISONVROD240EXT	
ISONVROD270EXT	Stainless Steel 304
ISONVROD300EXT	

## ISONV EARLY STREAMER EMISSION TERMINAL ADAPTOR



- Adaptor to interface Early Streamer Emission Terminal with ISOonV Insulated Conductor

Part Number	Material
ISONVESE	Stainless Steel

## ISONV CONCRETE BLOCK SUPPORT ASSEMBLY



- Used to ballast mast stands on horizontal surfaces

Part Number	Material
ISONVBLOCKSET1	
ISONVBLOCKSET2	
ISONVBLOCKSET3	Concrete (Block), Stainless Steel 304 (Threaded Rod)
ISONVBLOCKSET4	
ISONVBLOCKSET5	

## ISONV CONCRETE BLOCK SUPPORT ASSEMBLY, INCLINED SURFACE



- Used to ballast mast stands on inclined surfaces
- Use in conjunction with Threaded Rod Extensions.

Part Number	Material
ISONVBLOCKSET1K	
ISONVBLOCKSET2K	
ISONVBLOCKSET3K	Concrete (Block), Stainless Steel 304 (Threaded Rod), Aluminum (Knuckle Joint)
ISONVBLOCKSET4K	
ISONVBLOCKSET5K	

## CABLE TIE

- Strap for securing downconductor

Part Number	Length	Material
LPTIESS25	360 mm	Stainless Steel 316 with Black Polyester/Epoxy Coating

# Index

Part Number	Pages	Part Number	Pages
ISONV50	16	ISONVBKTR50	19
ISONV70	16	ISONVBKTR70	19
ISONVSEAM10	16	ISONVSTRAPBKT	19
ISONVTILE	16	ISONVROD200EXT	20
ISONVCORR10	16	ISONVROD240EXT	20
ISONVFS	16	ISONVROD270EXT	20
ISONVBLOCK4KG	16	ISONVROD300EXT	20
ISONVSTRAPFS	16	ISONVESE	20
ISOTMN50KITU	17	ISONVBLOCKSET1	20
ISOTMN70KITU	17	ISONVBLOCKSET2	20
ISOTMN50KITUA	17	ISONVBLOCKSET3	20
ISOTMN70KITUA	17	ISONVBLOCKSET4	20
ISOTMN50KITL	17	ISONVBLOCKSET5	20
ISOTMN70KITL	17	ISONVBLOCKSET1K	20
ISONVEBL50	17	ISONVBLOCKSET2K	20
ISONVEBL70	17	ISONVBLOCKSET3K	20
MPSC404SS	17	ISONVBLOCKSET4K	20
MPSC404SSA	17	ISONVBLOCKSET5K	20
ISONVSTRAPC	17	LPTIESS25	20
ISONVSTRAP	17		
ISONVSTRIP	18		
ISONVSTRIP50	18		
ISONVSTRIP70	18		
ISONVSTRIPCS	18		
ISONVSTRIPBL	18		
LPAAT0500	18		
LPAAT1000	18		
LPAAT1500	18		
LPAAT2000	18		
LPSAT1000	18		
LPSAT2000	18		
ISONVMAST11	18		
ISONVMAST24	18		
ISONVMAST37	18		
ISONVMASTA11	18		
ISONVMASTA24	18		
ISONVMASTA37	18		
ISOMASTASSY	19		
ISONVSTAND10	19		
ISONVSTAND15	19		
ISONVSTAND25	19		
ISONVBKTXL	19		
ISONVBKT15	19		
ISONVBKT80	19		
ISONVBKT200	19		
ISONVBKT50X50	19		
ISONVBKTR40	19		





Our powerful portfolio of brands:

**CADDY   ERICO   HOFFMAN   RAYCHEM   SCHROFF   TRACER**



[nVent.com/ERICO](http://nVent.com/ERICO)

©2019 nVent. All nVent marks and logos are owned or licensed by nVent Services GmbH or its affiliates. All other trademarks are the property of their respective owners.  
nVent reserves the right to change specifications without notice.

ERICO-SB-H85107-ISOnV-UKEN-1909