



CONNECT AND PROTECT

nVent ERICO Isolated Downconductor ISOOnV Installation Instructions

Contents

1. Safety/Warnings	4
2. Isolated LPS Design	6
2.1 Standards	6
2.2 Explanation and calculation of separation distance	6
2.2.1 Separation Distance.....	6
2.2.2 Insulated conductors.....	7
2.3 Air termination system	7
2.4 Earth termination system	8
2.5 Isolated system examples	9
2.5.1 Separate downconductors	9
2.5.2 Complete building coverage	10
2.5.3 Connecting to lower non-isolated LP systems	11
2.5.4 Protection of specific items or people.....	11
3. System Overview	12
3.1 Air termination rods.....	13
3.2 Upper mast assembly.....	13
3.3 Lower section, and mounting arrangements.....	13
3.4 Insulated downconductors.....	14
4. Installation Details	15
4.1 Upper termination	15
4.2 Assembly and downconductor positioning	17
4.3 Mounting arrangements	22
4.3.1 Mast stands	22
4.3.2 Mast brackets	27
4.4 Conductor fastening and routing	32
4.5 Lower termination.....	34
4.6 Conductor function and terminations required	35
4.7 Clearance zones.....	35
4.8 Lightning Event Counter.....	37
5. Ordering Guide.....	38
6. ISOOnV System Parts	41
7. Glossary	46
8. Index	47

1. Safety/Warnings

SAFETY INSTRUCTIONS: All governing codes and regulations and those required by the job site must be observed. Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.



Due to ongoing research into the phenomena of lightning, lightning protection technology and product improvement, nVent reserves the right to alter any information and specifications contained herein at any time without notice.

The nVent ERICO Isolated Downconductors (ISOOnV) system uses a specialized lightning protection downconductor, that during operation may be subjected to impulse currents of over 100,000 Amps and voltages of up to 700,000 V may be developed.

Reliable operation is dependent upon correct design and installation in accordance with IEC 62305 series and nVent instructions.

The insulated downconductor must not be damaged in handling, installation or service. The downconductor sheath is a specialized semi-conductive material requiring connection to the equipotential bonding system of the building in accordance

with these instructions. This sheath is fragile and damage to the sheath may require replacement of the cable.

Fully refer to installation instructions prior to handling and installation. Do not assume that traditional lightning protection or HV cable practices apply.

These products should be installed as part of an IEC 62305 series integrated lightning protection system (LPS).

Lightning is a statistical phenomena where 100% protection is virtually impossible to achieve, and certainly, is not economically practical. However, correct installation is essential for the maximum level of safety.

Only install system during storm-free periods. Do not install in close proximity to overhead power lines. Do not expose personnel to electromagnetic radiation sources such as live transmission equipment during installation.

1. Safety/Warnings



1. nVent ERICO products shall be installed and used only as indicated in nVent ERICO product instruction sheets and training materials. Instruction sheets are available at www.nVent.com and from your nVent ERICO customer service representative.



3. All instructions must be completely followed to ensure proper and safe installation and performance.



4. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death.



2. Isolated LPS Design

This section gives a brief introduction to isolated LPS design. More details can be found in the standards referenced.

Note that throughout this document various terms are used. It may be helpful to refer to the Glossary at the end of this document for an explanation of these terms.

2.1 STANDARDS

The ISOv system is designed to comply with the requirements of the IEC 62305-3 and IEC TS 62561-8 Lightning Protection System (LPS) standards. The IEC 62305 series of standards provides a comprehensive approach to Lightning Protection System design, and part 3 of that series (IEC 62305-3) covers physical damage to structures, addressing both non-isolated LPS and isolated LPS. The ISOv conductors and associated accessories are assessed to these standards and provide an innovative method for implementing an isolated LPS that has a number of benefits.

2.2 EXPLANATION AND CALCULATION OF SEPARATION DISTANCE

2.2.1 Separation Distance

A fundamental requirement of implementing an isolated LPS is a good understanding of separation distance. Put simply, separation distance is the minimum distance between a point on the LPS conductor network and another conductive part that must be observed to avoid an undesired flashover from the LPS system to that conductive part, potentially causing damage. Such an undesired flashover is sometimes known as dangerous sparking.

This flashover is caused by the voltage rise on the LPS conductor network that occurs due to lightning current flow. The voltage is greatest (and hence separation distance requirement is greatest) at the top of the structure at the actual air terminations, and decreases on the lower parts of the building closer to the earth termination system. The voltage rise is most pronounced where single individual downconductors are used, and is markedly reduced where many downconductors share the lightning current.

Examples of this are given of in Section 2.4.

The calculation of the separation distance, s , is explained in the standard and is as follows.

$$s = \frac{k_i}{k_m} \times k_c \times l$$

where:

k_i depends on the chosen class of LPS (see below).

k_m depends on the electrical insulation material (see below).

k_c depends on the (partial) lightning current flowing on the air termination and the downconductor. Calculation of k_c can be a relatively complex, depending on the interconnection arrangement of conductors and downconductors.

l is the length, in metres, along the air termination and the downconductor from the point where the separation distance is to be considered to the nearest equipotential bonding point or the earth termination system.

Note that the length l along the air termination and

downconductor system can be ignored (assumed to be zero) where the structure is continuously conductive (for example, a metal framed structure with bonded metallic roofing).

The values of the parameters are as follows.

Class of LPS	k_i	Material	k_m
I	0.08	Air	1
II	0.06	Concrete, brick, wood	0.5
III and IV	0.04		

Number of Downconductors n	k_c
1 (only in case of an isolated LPS)	1
2	0.66
3 and more	0.44

Table 1 - Parameters used in separation distance calculation

NOTE - Values for k_c shown apply for all type B earthing arrangements and for type A earthing arrangements (see section 2.4 for an explanation of these earthing arrangements), provided that the earth resistance of neighboring earth electrodes do not differ by more than a factor of 2. If the earth resistances of single earth electrodes differ by more than a factor of 2, $k_c = 1$ is to be assumed. In practice, often a more detailed calculation of k_c is carried out using computer software.

So, in summary, separation distance is the minimum distance between a point on the LPS conductor network and another conductive part that must be observed to avoid an undesired flashover from the LPS system to that conductive part. To keep the calculation simple, the distance can be calculated for air, and if a conductive path is being considered (i.e. through a wall, or along a surface), the required distance is doubled.

The standards give example calculations for different situations to clarify how the technique is applied.

2. Isolated LPS Design

2.2.2 Insulated conductors

In practice, it can be difficult to maintain the required separation distance. To do so can require inconvenient routing of the conductors, or possibly elevating the conductor with insulating supports. In addition, it can be difficult to verify the presence, or otherwise, of any earthed items behind surfaces or within structural elements that would violate the required separation distance.

To simplify these issues, an insulated conductor can be used. The performance of the insulation is tested in a laboratory, with the result being expressed as the conductor having an equivalent separation distance to that provided by that distance of air. The test is specified in the standards and specifications previously mentioned.

The application of such a cable is relatively straightforward. The separation distance (in air) is calculated for various points on the lightning protection system. For those parts of the LPS where the insulated conductor is to be used, it must be ensured that:

The calculated separation distance (in air) \leq the conductor's equivalent separation distance

If this is so, the insulated conductor can be used in that part of the LPS, and the usual physical separation required does not apply. That is, the conductor can directly mount against earthed items without risk of dangerous sparking.

nVent manufactures two insulated conductors, having equivalent separation distances of 0.50 m, and 0.70 m.

2.3 AIR TERMINATION SYSTEM

The start of an LPS design using the ISOOnV system begins by ensuring coverage of the building or facility using the Protection Angle Method, Rolling Sphere Method, or a combination of both. The ISOOnV system inherently uses masts and longer rods, thus enabling greater protective areas with fewer rods, with any of these methods. This aspect of the design is similar for both an isolated and non-isolated system, but the isolated system design uses only dedicated air terminations, rather than including natural elements of the building, to ensure isolation of the LPS in the area where isolation is required.

Examples of the Protection Angle Method, Rolling Sphere Method, and a combination of both methods are shown here.




Figure 1 - Rolling Sphere method




Figure 2 - Protection Angle Method

2. Isolated LPS Design




Figure 3 - Combination of both methods

2.4 EARTH TERMINATION SYSTEM

The IEC 62305-3 standard identifies two basic types of earth termination systems.

The Type A arrangement has earth electrodes installed outside the structure to be protected connected to each downconductor, and these earth electrodes do not form a closed loop.

The Type B arrangement comprises either a ring conductor external to the structure to be protected, or a foundation earth electrode forming a closed loop. Such earth electrodes may

also be meshed, often being embedded in the concrete of a building foundation. The intention is that the potential difference between parts of the earth termination system is minimized.

More details of these earthing arrangements are given in the standard, but the basic idea is given in these illustrations. The type of earth electrode system is important when isolated LPS are used, and affects the calculation of separation distance.




Figure 4 - Type A and Type B earthing arrangements

2. Isolated LPS Design

2.5 ISOLATED SYSTEM EXAMPLES

2.5.1 Separate downconductors

In this example, each air termination rod has its own dedicated downconductor, noting that the use of a single downconductor for an isolated LPS air termination is permissible according to the standard. All the lightning current resulting from a strike to the air termination passes down that dedicated downconductor. In this case, the calculation of the separation distance at any point of that downconductor is simple, and is calculated from the previous formula given for separation distance, given that $k_m = 1$, $k_c = 1$, and k_i is in accordance with chosen class of LPS. If the equivalent separation distance of the cable is not to be exceeded, then the maximum individual conductor lengths are as follows.

Conductor	Class of LPS		
	I	II	III and IV
ISONV50	6.3 m	9.4 m	12.5 m
ISONV70	8.8 m	13.1 m	17.5 m

Table 2 - Maximum conductor length for individual non-interconnected conductors

Two examples are given using this approach.

The first example consists of a taller modern concrete reinforced building, complete with bonded metallic roofing. Careful attention has been made during building construction to ensure all concrete reinforcement is electrically interconnected, along with interconnection to the metallic roof cladding and supports, exposed metallic building elements, and connected into the building foundation earthing system. The building itself is inherently protected against direct lightning strikes, but sensitive electrical equipment has been installed on a mast on the rooftop. While the equipment and mast could be bonded into the building LPS system, it has been decided to avoid direct lightning currents flowing through the equipment by installing an isolated LPS system on the mast to protect that equipment, which will bond into the main building LPS system at the base of the mast. In this example, the length of isolated conductor required was 8 metres, and the LPS Class was level I, so ISONV70 was chosen (8 m is less than the maximum 8.8m allowable for ISONV70).

In this second example, a relatively compact building containing sensitive communications equipment needs to be protected. In addition to the sensitive building contents, exposed antenna systems have been installed on the rooftop. Four air termination rods are installed at each building corner, and the rolling sphere method confirms protection of the building and rooftop installations. The length of each downconductor to the building foundations is 6 metres. ISONV50 conductor was used, achieving an LPS Class I level of protection.

Note that the earthing system at the base of each downconductor can be of either Type A or Type B.




Figure 5—Separate downconductors (example 1)




Figure 6—Separate downconductors (example 2)

2. Isolated LPS Design

2.5.2 Complete building coverage

In this example, the building is significantly larger. There are a number of rooftop communication systems with antennas and PV arrays. A relatively quick analysis shows that running individual downconductors from each air termination exceeds the maximum cable length allowable. The air terminations are now interconnected, thus splitting the current via many paths, and in turn reducing the k_c factor, and hence the separation distance required. In this example, the building is 30 m x 30 m in plan view and 3 stories high (10 m high). Air terminations are installed at each corner, at the middle of each side, and one in the centre, for a total of 9 air terminations in a 3 x 3 array. The dimensions of the resulting system are as shown in the illustration. Note that, as explained in Sections 2.2 and 2.4, a Type B earthing system has been employed to ensure a good equipotential connection at the base of each downconductor.

Allowing for the heights of the air terminations, computational software calculated the separation distances for the corner, edge, and center air terminations to be as follows.

Air Termination	Class of LPS	I	II	III and IV
Corners	0.56 m	0.42 m	0.28 m	
Edges	0.48 m	0.36 m	0.24 m	
Centres	0.60 m	0.45 m	0.30 m	

Table 3 - Separation distances required at each Class of LPL




Figure 7—Complete building coverage

2. Isolated LPS Design

2.5.3 Connecting to lower non-isolated LP systems

In this situation, equipment on a rooftop is required to be protected by an isolated LPS, but the whole building is not in need of a complete isolated LPS. It may make good economic sense to connect the isolated rooftop LPS into the non-isolated LPS covering the remainder of the building. There are two cases, depending on whether the building is conductive or not.

Building is conductive

This situation has been covered by the first example in Section 2.5.1, and is an excellent cost-effective application of the ISOvN system.

Building is non-conductive

In this example, the building is a masonry (non-conductive) building, and only the rooftop conductors use the ISOvN system. The separation distances are as calculated before, in Table 2. Note that since the building is non-conductive, the separation distance at the start of the ISOvN conductors (shown as point A in the illustration) has been calculated to be 0.3 m, and so electrical equipment needs to be located away from these points.

Since the main building downconductors are not isolated, care needs to be exercised to ensure no electrical services are located within the separation distance that applies at any particular point near those downconductors. This separation distance applies for internal conductors on the inside of the wall near these downconductors as well.

2.5.4 Protection of specific items or people

In some non-isolated LPS installations, the separation distance might only be violated at a particular item. In this instance, a length of insulated conductor can be used at that point. Sufficient length would have to be provided on each side of the item.

Another similar case would be where people are unavoidably near a downconductor, and the clearance does not exceed the




Figure 8—Connecting to lower non-isolated LP systems

separation distance. Such a case might be as shown in the following figure.

In this case, the downconductors in the vicinity of people could use insulated conductors. In this case, the isolated downconductor could be run in a non-metallic PVC pipe to help prevent physical damage to the conductor.




Figure 9—Flashover to people

3. System Overview

The system consists of insulated masts supporting lightning rods that provide the protective areas over the building, and interconnected insulated downconductors to maintain the system isolation. Note that the mast always is used with an inside conductor, and may have from 1 to 4 outside conductors.




Figure 10-ISOOnV air terminal support arrangement

3. System Overview

3.1 AIR TERMINATION RODS

The air terminals are available in lengths of 0.5, 1.0, 1.5, and 2.0 meters, and are chosen depending on overall height required by the LPS design. All are available in aluminium, with the 1.5 and

2.0 meter rods also available in V2A (304) grade stainless steel. They have M16 threaded bases to allow them to connect into the mast cap and upper termination.

3.2 UPPER MAST ASSEMBLY

The selected air terminal connects to a pre-assembled upper mast assembly, consisting of a mast cap, a 2 meter fiberglass mast, and a V2A (304) grade stainless steel coupler. The overall length of this assembly is 2.3 meters, and the coupler contains an internal equipotential bond device for electrically bonding


an internal downconductor. It is possible to mount additional downconductors down the outside of this upper mast assembly, but an internal downconductor is always required.

3.3 LOWER SECTION, AND MOUNTING ARRANGEMENTS


The lower mast section is constructed of aluminium, and comes in three choices of length – 1.1, 2.4, and 3.7 meters. This lower mast section is supported in a number of possible ways. It can utilize a 4-leg free-standing mast stand (as shown above), or be attached to a supporting pole or wall section.

The lower mast sections are available in two types - with or

without an opening (outlet) to allow the internal cable to exit out the side. Generally, when the lower mast section is fastened to a supporting pole or wall section, the internal cable simply exits the mast section out the bottom, and thus there is no need for a side opening. Lower mast sections used with mast stands, however, do need to have the opening.



(a)



(b)

Figure 11 – Lower mast section (a) without outlet, and (b) with outlet

3. System Overview

3.4 INSULATED DOWNCONDUCTORS

The insulated downconductors used in the system have a specially designed layered insulation that provides both the electrical insulation and voltage control. They are tested according to the requirements of IEC TS 62561-8, and have equivalent separation distances as follows:

Downconductor	Equivalent Separation Distance
ISONV50	50 cm (0.5 m)
ISONV70	70 cm (0.7 m)

Table 4 - ISONV downconductor equivalent separation distances

Each of these ISONV insulated downconductors achieve the highest lightning current carrying capability classification, having been tested to the H2 (200kA) Class tests.

Care must be exercised during installation not to damage the conductor insulation and maintain the required system isolation.




Figure 12- ISONV70 (above) and ISONV50 (below)

4. Installation Details

4.1 UPPER TERMINATION

The upper termination components are supplied in two kits, depending on whether the termination is for an insulated downconductor installed on the inside or outside of the mast. The kit contents for both these variants are shown in the mast assembly figure.

Regardless of which kit is used the actual upper termination is created the same way, as follows.

Clean the end of the downconductor

First clean the end of the downconductor with a cleaning cloth in the first 150 mm.




Figure 13 - Conductor area to clean

Strip the downconductor

Set the strip length on the special stripping tool to 30 mm. Then twist the tool clock-wise to strip the insulation, exposing 30 mm of the inner conductor.




Figure 14 - Stripping of the conductor

4. Installation Details

Attach the upper termination piece

Use a 19 mm wrench to screw the upper termination piece clockwise onto the end of the cable, checking that the conductor strands are visible through each screw hole.




Figure 15 - Attaching the upper termination piece

Tighten the two conductor fixing screws to 5 Nm, using the supplied hex key tool.




Figure 16 - Tighten fixing screws

Apply heat shrink tubing

Finally, using a gas torch or heat gun, slide the heat shrink tubing over the upper termination piece, ensuring that the two screws just tightened are covered, while the screw needed to fasten the air termination must remain uncovered. Secure the heat shrink tubing 15mm from the end of the coupler. Carefully heat the heat shrink tubing from the coupler end to the conductor, end leaving no trapped air. Do not burn the heat shrink tubing. Some melted adhesive may appear at the ends of the heated tubing – this is normal.




Figure 17 - Applying heat shrink tubing

4. Installation Details

4.2 ASSEMBLY AND DOWNCONDUCTOR POSITIONING

For a mast assembly, one terminated downconductor is mounted inside the supporting mast, and additional terminated downconductors may be mounted outside the supporting mast,

depending on the system design. The following figure shows the parts and how they are supplied.




Figure 18—Exploded view of mast assembly

(*) These parts used if an externally mounted downconductor is used.

(**) Required to be connected if lower mast section is not earthed through the mounting arrangement used.

4. Installation Details

The assembly process is as follows:




Figure 19—Join the upper and lower mast pieces

- a.** Regardless of the number of downconductors on the mast, begin by laying the parts on a horizontal surface.
- b.** Insert the lower mast section (16) into the upper mast assembly (10), and tighten the two lower mast section fixing bolts (15) to a torque 6 N.m.




Figure 20—Temporarily remove the internal Equipotential Bond bolt

- c.** Temporarily remove the internal Equipotential Bond tightening bolt (14). This bolt is colored black to avoid confusion.



Figure 21—Pass the internal conductor through mast

- d.** Pass the terminated internal ISOvN downconductor (18) through the joined lower mast section (16) and the upper mast assembly (10).

4. Installation Details




Figure 22—Loosely assemble the air terminal pieces

- e.** Twist the air terminal locking nut (2) completely up the threaded section of the air terminal (1), and pass the threaded end of the air terminal (1) through the split locking washer (3), the flat washer (4), the multi downconductor adaptors (7) if present, the mast cap (8), and the stabilizer (9).




Figure 23—Fasten conductor to the air terminal by hand

- f.** While holding the downconductor end (18) with one hand, screw the air terminal (1) clockwise to screw it into the upper termination on the internal ISOOnV downconductor (18). Tighten as firmly as possible by hand.




Figure 24—Tighten locking nut

- g.** Turn the air terminal nut (2) clockwise, and tighten to a torque 50 N.m.

4. Installation Details




Figure 25—Fasten mast cap to the upper mast assembly

h. Push the mast cap (8) fully onto the top of the upper mast assembly (10), ensuring that the stabilizer (9) fits fully into the top of the upper mast assembly (10), and tighten the three fixing set screws on the mast cap (8) to a torque of 2-3 N.m, ensuring that any multi downconductor adaptors (7) line up with the holes for the externally mounted ISOOnV downconductor equipotential bonds (13) below.




Figure 26—Reinsert the internal Equipotential Bond bolt and tighten

i. Replace the internal Equipotential Bond tightening bolt (14), removed in step c. above, and fully tighten to a torque of 6 N.m.

If externally mounted terminated ISOOnV downconductors (11) are to be installed, continue with the following steps:




Figure 27—Attach any external conductors as required

j. Fix each externally mounted terminated ISOOnV downconductor (11) to its multi downconductor adaptor (7) using the bolt (5) and split locking washer (6). Tighten to a torque of 50 N.m.

4. Installation Details




Figure 28—Remove and discard plastic thread protectors as required

k. Locate the appropriate threaded holes (13) in the coupling unit and remove the plastic thread protectors and discard.




Figure 29—Fasten conductors to the mast using the external equipotential bond clamps

l. Squeeze the external equipotential bond clamps (12) over each ISOnV downconductor (11), and fasten to the coupling unit using the bolt and lock washer supplied with the external equipotential bonds (12). Tighten to a torque of 6 N.m.



Figure 30—Fasten conductor to lower mast section as required

m. Apply stainless steel cable ties to fasten the ISOnV downconductors (11) to the lower mast section 16 as required. DO NOT overtighten, to avoid damage to the insulation!

To assist with part selection, the following table is provided:

Part in Figure 18	nVent ERICO Part Number
(1), (2)	e.g. LPAAT1000 (Air terminal)
(8), (9), (10), (13), (14), (15)	ISONVMASTASSY (Upper Mast Assembly)
(16)	e.g. ISONVMAST24 (2.4 m lower mast, for use with mast brackets), or ISONVMASTA24 (2.4 m lower mast, for use with mast stand)
(3), (4), (17), (18)	ISOTMN50KITU (Upper Termination Kit, Inside Mast) + ISONV50, or ISOTMN70KITU (Upper Termination Kit, Inside Mast) + ISONV70
(5), (6), (7), (11), (12)	ISOTMN50KITUA (Upper Termination Kit, Outside Mast) + ISONV50, or ISOTMN70KITUA (Upper Termination Kit, Outside Mast) + ISONV70

In addition, see Section 6 "Ordering Guide".

4. Installation Details

4.3 MOUNTING ARRANGEMENTS

Once the mast assembly is completed as per the previous section, the mounting arrangement needs to be implemented.

There are two basic arrangements – using masts stands, and using brackets.

4.3.1 Mast stands

The mast stands for the ISOOnV system have four legs and mounting points, and are supplied folded up, ready to be unfolded on site.



Figure 31–Unfolding the mast stand

The mast stands are available in three different sizes (1.0 m, 1.5 m, and 2.5 m) to suit total mast heights of 3.4 m, 4.7 m, and 6.0 m. Note that the air terminal lengths and height of any concrete blocks are additional to these mast heights.

On occasion, the roof construction may permit the mast stands to be directly mounted using suitable fastenings. Often, however, it is desirable to avoid puncturing the roofing membrane, or adequate direct mechanical fastening cannot be assured. In these cases, the mast stand is fitted with concrete blocks to provide solid positioning. The number and arrangement of these concrete blocks depends on the roof pitch and maximum wind speeds in the particular installation location. Each individual concrete block weighs 17 kg, and block stacks of 1 to 5 blocks, complete with foam base, connecting rod, and fastening hardware are available. Please contact nVent for engineering guidance.




Figure 32–Concrete block arrangement on a horizontal location

4. Installation Details

When a horizontal installation is done with concrete blocks, the block arrangement is as follows:




Figure 33—Concrete block stack for mast stand on a horizontal location

Fit the foam base and concrete blocks to the rod and tighten the washers and nut (as shown above) down onto the concrete stack to hold them securely in place. Tighten to 50 N.m.

Adjust the upper two nuts and split washers to the correct height, ensuring that the mast stand feet tabs are located between the two split washers. This adjustment allows for uneven surfaces. Once at the correct height, tighten the top nut down to a torque of 50 N.m.

Where the installed location is not horizontal, an adjustable angle fitting is available that accommodates a range of roof pitches.




Figure 34—Concrete block arrangement on a sloping location

4. Installation Details

In this case the block stack comes with variable angle knuckle and rod height to suit the number of blocks. In addition, an extension rod set is used to provide the vertical rod connecting to the mast stand. These are available in different lengths to suit the particular roof and mast stand parameters. Please contact nVent for engineering guidance with regard to the maximum roof angle advisable and other recommendations with this sloping roof arrangement.




Figure 35—Extension rod used with Concrete block set with knuckle and rod

4. Installation Details

Once the mast stand is secured into its final location, the mast stand and conductors are added. The mast stands feature an easy standing procedure to allow the mast to be stood into place into the mast stand as shown in the following illustrations.



Fig 36a



Fig 36b



Fig 36c



Fig 36d



Fig 36e

Figure 36—Fitting the mast to the mast stand

4. Installation Details

First the base of the lower mast section is placed into the receiving feature of the mast stand (Fig 36a). The mast is then stood up into position (Fig 36b). Note that safe working practices must be adopted to achieve this, and additional mechanical aids are often employed.

Once standing in place, a supporting collar is placed against the mast section and slid down into position (Fig 36c). Once in place, two bolts secure it in position (Fig 36d). Ensure the mast is rotated to the correct location to facilitate cable exit, then finally tighten the two lock bolts against the mast section (Fig 36e).

Note that just the lower mast is shown here for clarity. In practice, the mast will be fully assembled with conductors as per the above description. Ensure that the conductors are laid out properly in the appropriate direction before the lift, and are of sufficient length.

Raise the mast into position using safe working practices, and ensure that the ISONV conductor is not damaged during the lift.



Figure 37—Raise the mast using safe working practices

4. Installation Details

4.3.2 Mast brackets

Instead of using a mast stand, it is often more convenient to utilize an aspect of the existing structure to mount the mast. There are a number of brackets available to suit fixing to walls, masts, railings, etc.

Generally, either two or three brackets are required to adequately support the mast, with a typical spacing between the outer brackets of 1 m. Please contact nVent for engineering guidance with regard to the location and quantity of brackets required, and the bracket fastener retaining strengths required under differing environmental conditions.




Figure 38—Typical bracket spacing requirement

Mounting to a wall

There are three smaller brackets available, giving an offset distance from the wall of 15, 80, and 200 mm.




Figure 39—Smaller wall brackets

In addition, there is a larger bracket where the offset from the wall needs to be much larger. The bracket shown below gives an offset distance from the wall of 1000 mm.




Figure 40—Large wall bracket

4. Installation Details

Mounting to existing round items

There are three dedicated brackets for this, suiting existing round items of diameters in the following ranges: 40-50 mm, 50-60 mm, and 70-80 mm

The existing items being mounted to must be assessed as being suitable to withstand the additional load of the added ISOv mast structure.





Figure 41–Round mast brackets

Mounting to other items


A strap and clamp arrangement is available to allow the mast to be fixed to larger round items or other irregular shaped support structures.



(b) Clamp



(a) Strap



(c) Mast Bracket

Figure 42–(a) Strap, (b) Clamp, and (c) Mast Bracket

4. Installation Details

The parts for this arrangement are shown above, and shown used together below.

The strap (a) is cut to the length required, and passed thought the mast bracket (c) and the ends overlapped through the clamp (b). Rotate the arrangement around the support structure until the fastener is in the correct position, then tighten the bolt in the clamp to press down on the overlapping straps, fixing them into place. Ensure that the strap ends extend beyond the clamp by at least 50 mm as shown below.



Figure 43—Installed arrangement on large round pole

Where the round support structure is greater than 600 mm in diameter, a second clamp (b)* should be added as shown above in Figure 30 and tightened, further tensioning the strap, to ensure that it is fixed firmly in place. For irregular shaped support structures additional clamps (b)* may be required.




Figure 44—Overlap requirement of the strap ends in the clamp

4. Installation Details

Mounting to rectangular profile supports

Finally, when mounting the mast to square or rectangular profile, the following fitting can be used.

The fitting can accommodate up to a maximum of 50 mm x 50 mm sized section.

30 N.m




Figure 45—Fitting for mounting to a rectangular or square profile

Equipotential bonding

Note that the lower metallic section of the mast must be connected to the equipotential bonding system of the building. Where the method used to fix the mast provides this connection (for example, where the mast is fastened to a railing that is bonded to the equipotential bonding system of the building) no additional measures need to be taken. However, where the mast is effectively isolated from the building earthing system (such as when using free standing masts), a bonding conductor must be connected from the mast stand to the equipotential bonding system of the building. Where this conductor is 8 mm or 10 mm diameter rod conductor, the mast stand clamp may be used, as shown in the following figure. Smaller conductors, such as the minimum 6 mm² required, may be connected to the mast using the lug, washer and bolt as supplied with the inside upper termination kit (see figure 34).




Figure 46—Connecting the bonding conductor

4. Installation Details

Where the mast does not use a mast stand, and is fixed to an existing structure (using one of the bracket methods previously described), and the structure mounting location is NOT connected to the building earthing system, a 6 to 16 mm² bonding conductor must be connected from the mast itself to the equipotential bonding system of the building, as shown in the following figure. Note that the lug, washer and bolt required are supplied with the inside upper termination kit, and the threaded hole is already present in the mast section.




Figure 47—Connecting the bonding conductor to the lower mast section

4. Installation Details

4.4 CONDUCTOR FASTENING AND ROUTING

Fastening

It is very important that the ISOOnV cable is fastened at least every meter as per the requirements of IEC 62305-3.




Figure 48—Fasteners must be adequately fastened

The basic fastener for the ISOOnV50 and ISOOnV70 cables is shown.









Figure 49—Fastener ISOOnVFS

This is fastened to the horizontal or vertical surface by user supplied hardware. The mounting hole size is 6 mm.

In addition, there are a number of specialty fastening solutions that use this basic fastener.



(b)



(e)

Figure 50—Specialty fastening solutions

4. Installation Details

The basic fastener can be rotated on these fastening solutions to suit different conductor orientations, and they are as follows:

- a. ISONVSEAM – Clamps to the seam of roofing seams, and is fixed in place by the two clamping screws. Fits a seam with width up to 8 mm.
- b. ISONVTILE – Fits underneath roofing tiles, being retained by the back edge of the tile.
- c. ISONVCORR – Allows fixing to corrugated roofing systems. User supplied screws and waterproofing washers are used to suit the application.

- d. ISONVSTRAPFS – Designed to be used with parts (a) and (b) from Figure 43 in the same mounting situation as shown in that Figure.
- e. ISONVBLOCK4KG – The fastener is fixed with a 4 kg concrete block, with matching soft base, for use on flat roofs.

Routing

The cable is routed from air terminal mast to other air terminal masts or earth as per the design. It is important that the minimum bending radius of 400 mm is maintained.




Figure 51 – Maintain minimum bending radius requirements

4. Installation Details

4.5 LOWER TERMINATION

The lower termination is very similar to the upper termination, noting that the actual termination has a 10 mm diameter rod protrusion instead of a hole to receive an air termination. The kit contents are shown.

Lower Termination:

ISOTMN50KITL or ISOTMN70KITL



Figure 52—Lower termination kit contents

The lower termination is done in the same way as the upper termination, and the final termination should look as shown here:




Figure 53—Completed lower termination

Having completed the lower termination, it is connected into the existing lightning protection system, or to the earth termination system. To facilitate this connection, there are two connection components that allow for interconnection with round conductor, flat tape, or a ground rod.

The plates can be rotated to match the orientation of the conductors to be joined. The four corner bolts should be tightened to a torque of 23 N.m.



Part: MPSC404SSA	Part: MPSC404SS
 <p>Connects to:</p> <ul style="list-style-type: none">8 mm, 10 mm diameter Solid conductor35 mm² - 50 mm² Stranded conductor40 mm x 4 mm (max) Tape conductor	 <p>Connects to:</p> <ul style="list-style-type: none">5/8" to 3/4" nominal Earth electrode (actual diameter 14.2 – 19.0 mm)

Figure 54—Connectors for use with the lower termination

4. Installation Details

4.6 CONDUCTOR FUNCTION AND TERMINATIONS REQUIRED

There are three types of conductor functions, and the terminations required for each are shown in the following figure.

The mast conductors are used in the majority of uses discussed in this document. The arrangement used for protection of specific items is discussed in section 2.5.4. As the conductors need to be terminated before each mast is lifted into position, it is important that sufficient length is allowed for.




Figure 55-Conductor function and terminations required

4.7 CLEARANCE ZONES

To avoid direct flashovers through air and tracking failures, it is necessary to keep earthed objects (structural elements, mechanical supports, piping, aerial conductors, etc) away from the upper insulated portion of the mast. The figure below shows the zone that must be kept clear of these earthed items. It extends from the lightning rod, down to the coupling unit of the mast, at a radius given by the calculated separation distance at that point. To be conservative, the radius R can be made to be the equivalent separation distance of the ISONV conductor (50 cm for ISONV50, or 70 cm for ISONV70).




Figure 56–Clearance zone at the top of the mast

4. Installation Details

At the bottom end of the ISOOnV conductor a similar situation can occur. Where the lower termination connects directly to the earth termination network, a clearance zone is not required. However, if the lower termination connects into a non-isolated LP system on a non-conductive building (e.g. masonry building, see section 2.5.3 'Building is non-conductive') then a clearance zone is required.




Figure 57—Clearance zone at lower termination (non-conductive building)

The separation distance is calculated at the point where the lower termination connects to the non-insulated conductors (using, for example, a MPSC404SS connector). The length of the clearance zone from that point is $L = 2 \times S_{air}$, and the radius of the clearance zone is $R = S_{air}$. Any support required for the cable in this zone must be non-conducting, and at least length R .

In addition, an Equipotential Bonding Sheath Clamp should be fitted to the conductor immediately past the clearance zone, and connected to the equipotential bonding system of the building, using a 6 mm² bonding conductor as shown in Figure 43. Note that this Equipotential Bonding Sheath Clamp is not required where the lower termination connects directly to the earth termination network.

Where a particular electrical item in a non-isolated LPS is located within the separation distance of the LP conductor running past it, it would normally be required to be bonded to the LP conductor. Where this is not desirable (the item might be a surveillance camera, for example), and the LP conductor cannot be repositioned, it is possible to use a length of ISOOnV conductor in the vicinity of the item. The following figure shows this arrangement. The ISOOnV conductor needs to extend beyond the item on each side, and equipotential bonding clamps are fitted that connect to the equipotential bonding system of the building as shown. The item can be as close to the ISOOnV conductor as needed between these earthed two clamps.

4. Installation Details




Figure 58—Clearance zones when protecting a particular item of equipment

A clearance zone needs to be maintained between the earthed clamps and the terminations on the ISOOnV conductor. The radius and length of this clearance zone depends on the calculated separation distance at the terminations. If the lower termination connects directly into the earthing termination

system, a clearance zone is not required. This example is simplistic in that it is usually easier to relocate either the LP conductor or the item, but it illustrates the principles, and can be applied in more complex scenarios where this technique might be the most effective solution.

4.8 LIGHTNING EVENT COUNTER

If desired, a Lightning Event Counter (LEC) can be installed. It is a device for registering and recording the number of strikes intercepted. The LEC should be mounted in a secure area that is not prone to contact by moving items, theft or vandalism. However, it should be mounted in a location that allows safe access to inspect the display. Refer to instructions supplied with the LEC.

The LEC is fixed to the ISOOnV downconductor, and does not require additional fixing to the structure. Additional downconductor fixings should be installed directly above and below the LEC counter.

Note that to be most effective, the LEC is usually only installed in systems that involve a single downconductor from each air terminal, and is usually installed near the bottom end of the conductor.

5. Ordering Guide

The first flowchart below shows the parts needed for each mast being considered. The second flowchart shows the terminations, conductor, fasteners, and connectors needed, and assumes ISONV50 conductor is being used. If ISONV70 is being used change the "50" in the part numbers involved to "70". Note that in some designs, both ISONV50 and ISONV70 will be used on the same mast.




Figure 59—Ordering flowchart – Air terminal, mast, and supports

5. Ordering Guide




Figure 60—Ordering flowchart—Terminations, conductor, fasteners, and connectors

The flowcharts above are a starting point. Take care not to double up on conductors and terminations that go between masts. In addition, typically a stripping tool with the correct bushing to suit the conductor being used will be required.

As an example Bill of Material resulting from these flow charts, consider a freestanding mast on a corner of a building where one conductor runs down to the earthing system, and two others head to neighboring masts (not shown).

5. Ordering Guide




Figure 61—Example freestanding mast

The Bill of Material for the items shown is:

Part	Description	Quantity	Notes
LPAAT2000	2 m Air terminal	1	
ISOMASTASSY	Upper mast assembly	1	
ISONVMASTA37	3.7m Lower mast	1	
ISONVSTAND25	2.5 m Mast stand	1	
ISONVBLOCKSET3	3 Block set	4	
ISOTMN50KITU	Inside upper termination kit	1	Inside the mast
ISOTMN50KITUA	Outside upper termination kit	2	Outside the mast
ISONV50	Insulated conductor, SD = 0.5 m	30	
ISOTMN50KITU	Outside upper termination kit	2	Distant ends
ISOTMN50KITL	Lower termination kit	1	End going to earth rod
ISONVFS	Fastener	5	
ISONVBLOCK4KG	4 kg Concrete block with fastener	5	
MPSC404SS	Connector to earth rod	1	

Table 5—Example Bill of Material

6. ISOv System Parts

ISOv INSULATED CONDUCTOR



- Provides protection of equipment against lightning strike flashover by providing an insulated path to ground via an equivalent separation distance

Part Number	Equivalent Separation Distance	Material
ISONV50	50 cm	Copper, Polyethylene
ISONV70	70 cm	

ISOv CONDUCTOR CLAMP FOR SEAMED METAL ROOF



- Secures conductors to standing seam profiles
- Suits both ISOv50 and ISOv70

Part Number	Material
ISONVSEAM10	Stainless Steel 304 (conductor clamp), Galvanized Steel (seam clamp)

ISOv CONDUCTOR CLAMP FOR INTERLOCKING ROOF TILE



- Secures ISOv Insulated Conductor to roof tiles
- Suits both ISOv50 and ISOv70

Part Number	Material
ISONVTILE	Stainless Steel 304

ISOv CONDUCTOR CLAMP FOR CORRUGATED ROOF



- Secures ISOv Insulated Conductor to corrugated metal roofs

Part Number	Material
ISONVCORR10	Stainless Steel 304

ISOv CONDUCTOR FASTENER



- Secures lightning protection conductors and prevents displacement

Part Number	Material
ISONVFS	Stainless Steel 304

ISOv CONDUCTOR SUPPORT BLOCK



- Weighted ballast with cable fastener to support ISOv Insulated Conductor along rooftop
- Suits both ISOv50 and ISOv70

Part Number	Unit Weight	Material
ISONVBLOCK4KG	4 kg	Concrete (block), Stainless Steel 304 (conductor clamp)

ISOv CONDUCTOR STRAP BRACKET



- Secures conductors to round objects such as masts, pipes and columns
- Suits both ISOv50 and ISOv70
- Use in conjunction with ISOvSTRAP and ISOvSTRAPC

Part Number	Material
ISONVSTRAPFS	Stainless Steel 304

6. ISOv System Parts

ISOv UPPER TERMINATION KIT, INSIDE MAST



- Kit includes upper termination, heat shrink tubing, hex key wrench, air terminal washers and crimp ring terminal for bonding to mast

Part Number	Conductor Type	Material
ISOTMN50KITU	ISONV50	
ISOTMN70KITU	ISONV70	316L

ISOv UPPER TERMINATION KIT, OUTSIDE MAST



- Kit includes upper termination, heat shrink tubing, hex key wrench, air terminal washers, multi-cable adapter and an equipotential bond

Part Number	Conductor Type	Material
ISOTMN50KITUA	ISONV50	
ISOTMN70KITUA	ISONV70	316L

ISOv LOWER TERMINATION KIT



- Kit includes lower termination, heat shrink tubing, and a hex key wrench

Part Number	Conductor Type	Material
ISOTMN50KITL	ISONV50	
ISOTMN70KITL	ISONV70	316L

ISOv EQUIPOTENTIAL BOND KIT



- Used with ISOv lower terminations when equipotential bonding is required

Part Number	Conductor Type	Material
ISONVEBL50	ISONV50	Stainless Steel 304 (Conductor Bond), Tinned Copper (Terminal)
ISONVEBL70	ISONV70	

MULTI-PURPOSE GROUNDING CLAMP, STAINLESS STEEL



- Convenient multi-purpose clamp designed to accommodate round conductors, flat conductors, ground rods and rebar

Part Number	Earth Rod	Material
MPSC404SS	14.2–19.0 mm Diameter, Actual (Ø)	Stainless Steel 304

MULTI-PURPOSE GROUNDING CLAMP, STAINLESS STEEL



- Cross connector for round-to-round, round-to-tape, and tape-to-tape connections

Part Number	Conductor Size	Material
MPSC404SSA	8 mm Solid-10 mm Solid, 35 mm ² Stranded-50 mm ² Stranded 40 mm x 4 mm max. Tape	Stainless Steel 304

ISOv STRAP CLAMP



- Fastens ISOv Strap
- Use in conjunction with ISOvSTRAP and either ISOvSTRAPBKT or ISOvSTRAPFS

Part Number	Material
ISONVSTRAPC	Stainless Steel 304

ISOv STRAP



- Provides variable fastening on poles, masts and pipes
- Use in conjunction with ISOvSTRAPC and either ISOvSTRAPBKT or ISOvSTRAPFS

Part Number	Length	Material
ISONVSTRAP	50 m	Stainless Steel 304

6. ISOOnV System Parts

ISONV STRIPPING TOOL HANDLE



- For use with ISOOnV Stripping Tool Bushings to provide precise strip length of ISOOnV Insulated Conductor

Part Number	Material
ISONVSTRIP	Thermoplastic, Steel and Brass

ISONV STRIPPING TOOL BUSHING



- For use with ISOOnV Stripping Tool Handle to provide precise strip length of ISOOnV Insulated Conductor

Part Number	Conductor Type	Material
ISONVSTRIP50	ISONV50	Thermoplastic,
ISONVSTRIP70	ISONV70	Stainless Steel Blades

ISONV STRIPPING TOOL CARRYING CASE



- Designed to carry ISOOnV stripping tool handle, bushing and replacement blades

Part Number	Material
ISONVSTRIPCS	Polyethylene

ISONV STRIPPING TOOL REPLACEMENT BLADE

- Replacement blades for ISOOnV Stripping Tool Bushing

Part Number	Material
ISONVSTRIPBL	Stainless Steel

ISONV AIR TERMINAL



- Lightning strike termination points for use with air terminal bases

Part Number	Height	Material
LPAAT0500	500 mm	Aluminum
LPAAT1000	1,000 mm	
LPAAT1500	1,500 mm	
LPAAT2000	2,000 mm	
LPSAT1000	1,000 mm	Stainless Steel 304
LPSAT2000	2,000 mm	

ISONV LOWER MAST



- For use with ISOOnV Upper Mast Assembly in vertical cantilever installations

Part Number	Material
ISONVMAST11	Aluminum
ISONVMAST24	
ISONVMAST37	

ISONV LOWER MAST WITH OUTLET



- For use with ISOOnV Upper Mast Assembly in mast stand installations

Part Number	Material
ISONVMASTA11	Aluminum
ISONVMASTA24	
ISONVMASTA37	

6. ISOv System Parts

ISOv UPPER MAST ASSEMBLY



- For use with ISOv lower masts

Part Number	Material
ISOMASTASSY	Polypropylene (cap), Fiberglass (mast), Stainless Steel 304 (coupler)

ISOv MAST STAND



- Used to support ISOv mast assemblies with an outlet

Part Number	Material
ISONVSTAND10	
ISONVSTAND15	Stainless Steel 304
ISONVSTAND25	

ISOv ADJUSTABLE OFFSET MAST BRACKET



- Telescoping mast support for mounting under roof overhang

Part Number	Offset Distance	Material
ISONVBKTXL	800 – 1,000 mm	Stainless Steel 304


ISOv FIXED OFFSET MAST BRACKET



- Use for cantilevered mounting ISOv masts

Part Number	Offset distance	Material
ISONVBKT15	15 mm	
ISONVBKT80	80mm	Stainless Steel 304
ISONVBKT200	200 mm	

ISOv SQUARE RAILING MAST BRACKET



- Secures masts to square railing

Part Number	Rail Size	Material
ISONVBKT50X50	50 mm x 50 mm	Stainless Steel 304

ISOv MAST TO PIPE BRACKET



- For mast-to-mast or pipe-to-mast mounting connections

Part Number	Pipe Outside Diameter	Material
ISONVBKTR40	40 – 50 mm	
ISONVBKTR50	50 – 60 mm	Stainless Steel 304
ISONVBKTR70	70 – 80 mm	

ISOv MAST STRAP BRACKET



- Secures masts to round objects such as masts, pipes and columns

Part Number	Material
ISONVSTRAPBKT	Stainless Steel 304

6. ISOv System Parts

THREADED ROD EXTENSION



- Used with concrete block supports for inclined surfaces for level installation of mast stands

Part Number	Material
ISONVROD200EXT	
ISONVROD240EXT	
ISONVROD270EXT	Stainless Steel 304
ISONVROD300EXT	

ISOv EARLY STREAMER EMISSION TERMINAL ADAPTOR



- Adaptor to interface Early Streamer Emission Terminal with ISOv Insulated Conductor

Part Number	Material
ISONVESE	Stainless Steel

ISOv CONCRETE BLOCK SUPPORT ASSEMBLY



- Used to ballast mast stands on horizontal surfaces

Part Number	Material
ISONVBLOCKSET1	
ISONVBLOCKSET2	
ISONVBLOCKSET3	Concrete (Block), Stainless Steel 304 (Threaded Rod)
ISONVBLOCKSET4	
ISONVBLOCKSET5	

ISOv CONCRETE BLOCK SUPPORT ASSEMBLY, INCLINED SURFACE



- Used to ballast mast stands on inclined surfaces
- Use in conjunction with Threaded Rod Extensions.

Part Number	Material
ISONVBLOCKSET1K	
ISONVBLOCKSET2K	
ISONVBLOCKSET3K	Concrete (Block), Stainless Steel 304 (Threaded Rod), Aluminum (Knuckle Joint)
ISONVBLOCKSET4K	
ISONVBLOCKSET5K	

CABLE TIE

- Strap for securing downconductor

Part Number	Length	Material
LPTIESS25	360 mm	Stainless Steel 316 with Black Polyester/Epoxy Coating

7. Glossary



ISOOnV – Is a proprietary system complying with relevant IEC standards, which allows the economic and convenient construction of an Isolated LPS.

Lightning strike – An electrical discharge between cloud and earth. Also called a Lightning flash.

Lightning Protection System (LPS) - In this document it is considered to be the external items consisting of an air termination system, downconductors, and an earth termination system. An LPS is intended to intercept lightning strikes and thereby prevent damage to structures and equipment. A more comprehensive definition for LPS would include internal items such as surge protective devices.

Isolated LPS – An LPS designed in such a way that the lightning current does not flow through any elements of the structure being protected. In an isolated LPS, dangerous sparks between the LPS and the structure are prevented.

Non-isolated LPS – An LPS designed in such a way as to be in electrical contact with the structure and to electrically bond (connect) with conductive structural elements. It is not generally isolated from the building electrical earthing system.

Air termination system – that part of the LPS constructed of metal designed to receive lightning flashes. In a non-isolated LPS, the air termination system may include conductive natural elements of the structure where appropriate and convenient. In an isolated LPS, the air termination system always consists of specially provided and installed air terminals, in order to keep lightning currents out of the structure.

Air terminal – A metallic item designed and installed with the function to receive a lightning strike. Also called a Lightning rod.

Downconductor – That part of the LPS designed to conduct the lightning current from the air termination system to the earth termination system.

Earth termination system – That part of the LPS designed to dissipate the lightning current into the general mass of earth. Usually comprised of some combination of the building foundation, buried bare conductors, and earth rods (ground rods). Also called a Grounding system.

Equipotential bonding system of the building - In this document, the equipotential bonding system is earthed, and is a part of the building earthing arrangement. It is usually constructed using Bonding bars, to which the electrical system earthing conductor is connected, along with communications systems earths, the LPS system, and other earthed items such as metallic structural elements.

Insulated conductor – a conductor with an insulating jacket, designed to carry lightning currents in an isolated LPS, performing as a downconductor.

Dangerous sparking - Electrical discharge due to lightning which causes physical damage in the structure to be protected. Occurs between the LPS and the structure or other metallic parts. Also known as a flashover.

Separation distance – The distance between two conductive parts at which no dangerous sparking or flashover can occur.

8. Index

Part Number	Pages	Part Number	Pages
ISONV50	41	ISONVBKTR40	44
ISONV70	41	ISONVBKTR50	44
ISONVSEAM10	41	ISONVBKTR70	44
ISONVTILE	41	ISONVSTRAPBKT	44
ISONVCORR10	41	ISONVROD200EXT	45
ISONVFS	41	ISONVROD240EXT	45
ISONVBLOCK4KG	41	ISONVROD270EXT	45
ISONVSTRAPFS	41	ISONVROD300EXT	45
ISOTMN50KITU	42	ISONVESE	45
ISOTMN70KITU	42	ISONVBLOCKSET1	45
ISOTMN50KITUA	42	ISONVBLOCKSET2	45
ISOTMN70KITUA	42	ISONVBLOCKSET3	45
ISOTMN50KITL	42	ISONVBLOCKSET4	45
ISOTMN70KITL	42	ISONVBLOCKSET5	45
ISONVEBL50	42	ISONVBLOCKSET1K	45
ISONVEBL70	42	ISONVBLOCKSET2K	45
MPSC404SS	42	ISONVBLOCKSET3K	45
MPSC404SSA	42	ISONVBLOCKSET4K	45
ISONVSTRAPC	42	ISONVBLOCKSET5K	45
ISONVSTRAP	42	LPTIESS25	45
ISONVSTRIP	43		
ISONVSTRIP50	43		
ISONVSTRIP70	43		
ISONVSTRIPCS	43		
ISONVSTRIPBL	43		
LPAAT0500	43		
LPAAT1000	43		
LPAAT1500	43		
LPAAT2000	43		
LPSAT1000	43		
LPSAT2000	43		
ISONVMAST11	43		
ISONVMAST24	43		
ISONVMAST37	43		
ISONVMASTA11	43		
ISONVMASTA24	43		
ISONVMASTA37	43		
ISOMASTASSY	44		
ISONVSTAND10	44		
ISONVSTAND15	44		
ISONVSTAND25	44		
ISONVBKTXL	44		
ISONVBKT15	44		
ISONVBKT80	44		
ISONVBKT200	44		
ISONVBKT50X50	44		

Our powerful portfolio of brands:

CADDY ERICO HOFFMAN RAYCHEM SCHROFF TRACER



nVent.com/ERICO

©2019 nVent. All nVent marks and logos are owned or licensed by nVent Services GmbH or its affiliates. All other trademarks are the property of their respective owners.
nVent reserves the right to change specifications without notice.

ERICO-TH-H84997-ISOnV-UKEN-1909