
DECLARATION OF CONFORMITY

MANUFACTURER	MYRRA S.A.
Address	2 boulevard de La Haye Bussy Saint Georges 77607 Marne la Vallée - FRANCE
Product	23989
Designation	CURRENT TRANSFORMER 1 / 500 - 90 A - 50 Hz
Power	90 A
Size	T31

This transformer conforms to the following requirements of EN 60950 and IEC 61558-2-16:

- Classification: incorporated, non short-circuit proof transformer
- Insulation class B (130°C) minimum
- Pollution degree 2
- Rated current 90 A
- Rated frequency 50 - 60 Hz
- CTI group III
- S / P (to be provided by the user):
 - Reinforced insulation
 - Test voltage 4000 V - 50 Hz - between P and a Ø 13.7 mm metallic rod put in the hole through the transformer.