

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Moulded Case Circuit Breaker

Type reference(s)

HHB, HNB Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-1:2007+Am1:2011-01+Am2:2015-04

BS EN 60947-2:2017-10+Am1:2020-02

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Mr Ian Ellis

Function of signatory

Certification Manager MDS

Place and date of issue

Telford, UK 16/12/2021

Signature

Ian Ellis

UKCA DECLARATION OF CONFORMITY

No. UKCA 21.3118.10.21

Type references

HHB Range

Product Reference	Product Description
HHB100Z	MCCB x250 3P 25ka 100A TM
HHB101Z	MCCB x250 4P 25ka 100A TM
HHB125Z	MCCB 250 3P 25ka 125A TM
HHB126Z	MCCB x250 4P 25ka 125A TM
HHB160Z	MCCB x250 3P 25ka 160A TM
HHB161Z	MCCB x250 4P 25ka 160A TM
HHB200Z	MCCB x250 3P 25ka 200A TM
HHB201Z	MCCB x250 4P 25ka 200A TM
HHB250Z	MCCB x250 3P 25ka 250A TM
HHB251Z	MCCB x250 4P 25ka 250A TM

HNB Range

Product Reference	Product Description
HNB100H	MCCB x250 3P 40ka 100A TM
HNB100Z	MCCB x250 3P 40ka 100A TM
HNB101H	MCCB x250 4P 40ka 100A TM
HNB101Z	MCCB x250 4P 40ka 100A TM
HNB125H	MCCB x250 3P 40ka 125A TM
HNB125Z	MCCB x250 3P 40ka 125A TM
HNB126H	MCCB x250 4P 40ka 125A TM
HNB126U	MCCB x250 4P 40ka 125A TM
HNB126Z	MCCB x250 4P 40ka 125A TM
HNB160H	MCCB x250 3P 40ka 160A TM
HNB160Z	MCCB x250 3P 40ka 160A TM
HNB161H	MCCB x250 4P 40ka 160A TM
HNB161Z	MCCB x250 4P 40ka 160A TM
HNB200H	MCCB x250 3P 40ka 200A TM
HNB200Z	MCCB x250 3P 40ka 200A TM
HNB201H	MCCB x250 4P 40ka 200A TM
HNB201Z	MCCB x250 4P 40ka 200A TM
HNB202H	MCCB x250 4P 40ka 200A TM
HNB250H	MCCB x250 3P 40ka 250A TM
HNB250Z	MCCB x250 3P 40ka 250A TM
HNB251H	MCCB x250 4P 40ka 250A TM
HNB251Z	MCCB x250 4P 40ka 250A TM
HNB252H	MCCB x250 4P 40ka 250A TM

UKCA DECLARATION OF CONFORMITY

No. UKCA 21.3118.10.21

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Telford
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes BS EN 60947-1 BS EN 60947-2 Yes Designated Before 2016
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method: Designated standard used
Certificate(s) / test report(s):	CB Test Certificate NL-64765 KRC-15404
Mark approval(s):	No
Product documentation :	See Hager Website
Comments:	BS EN Standard requirements are identical to EN standard

UKCA DECLARATION OF CONFORMITY

No. UKCA 21.3118.10.21

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 60947-2:2006	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	01/01/2021	0009/21
S.I. 2016 No. 1101	EN 60947-1:2007	Low-voltage switchgear and controlgear - Part 1: General rules	01/01/2021	0009/21

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 60947-1:2007	Low-voltage switchgear and controlgear - Part 1: General rules	01/01/2021	0007/21
S.I. 2016 No. 1091	EN 60947-2:2006	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	01/01/2021	0007/21

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------