

UKCA DECLARATION OF CONFORMITY No. 22.3187.06.22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

MCCB H1600ELE

Type reference(s)

HNF800U_HNF801U_HNF980H_HNF980U_HNF981H_HNF981U_
HNF990H_HNF990U_HNF991H_HNF991U_HEF980H_HEF980U_
HEF981H_HEF981U_HEF990H_HEF990U_HEF991H_HEF991U

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)

.....

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-2: 2017-10 + A1:2020-02

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Mr Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, 23th June 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22.3187.06.22

Type references

Type reference	Description
HNF800U	MCCB H1600 3 poles 800A Icu/Ics= 50/50kA LSI
HNF801U	MCCB H1600 4 poles 800A Icu/Ics= 50/50kA LSI
HNF980H	MCCB H1600 3 poles 1250A Icu/Ics= 50/50kA LS
HNF980U	MCCB H1600 3 poles 1250A Icu/Ics= 50/50kA LSI
HNF981H	MCCB H1600 4 poles 1250A Icu/Ics= 50/50kA LSI
HNF981U	MCCB H1600 4 poles 1250A Icu/Ics= 50/50kA LSI
HNF990H	MCCB H1600 3 poles 1600A Icu/Ics= 50/50kA LSI
HNF990U	MCCB H1600 3 poles 1600A Icu/Ics= 50/50kA LSI
HNF991H	MCCB H1600 4 poles 1600A Icu/Ics= 50/50kA LSI
HNF991U	MCCB H1600 4 poles 1600A Icu/Ics= 50/50kA LSI
HEF980H	MCCB H1600 3 poles 1250A Icu/Ics= 70/50kA LSI
HEF980U	MCCB H1600 3 poles 1250A Icu/Ics= 70/50kA LSI
HEF981H	MCCB H1600 4 poles 1250A Icu/Ics= 70/50kA LSI
HEF981U	MCCB H1600 4 poles 1250A Icu/Ics= 70/50kA LSI
HEF990H	MCCB H1600 3 poles 1600A Icu/Ics= 70/50kA LSI
HEF990U	MCCB H1600 3 poles 1600A Icu/Ics= 70/50kA LSI
HEF991H	MCCB H1600 4 poles 1600A Icu/Ics= 70/50kA LSI
HEF991U	MCCB H1600 4 poles 1600A Icu/Ics= 70/50kA LSI

UKCA DECLARATION OF CONFORMITY

No. 22.3187.06.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes Yes
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	Risk analysis 22.1876.06.22
Certificate(s) / test report(s):	CB Test Certificate No. NL-65233 Test Report No. 2243599.67 EU DofC No. KRC5917-1c Supplier Compliance Certificat KRC15235
Mark approval(s):	No marks
Product documentation :	See Hager Website
Comments:	BS EN Standard requirements are identical to EN Standards