

UKCA DECLARATION OF CONFORMITY No. UKCA 22.3191.04.22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

P4 H3 630A Switch Disconnecter

Type reference(s)

HCW (see next pages)

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-3:2021

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, le 20 Avril 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3191.04.22

Type references

Product Reference	Product Description
HCW400AR	SWITCH h3+ P630 3x400A
HCW401AR	SWITCH h3+ P630 4x400A
HCW630AR	SWITCH h3+ P630 3x630A
HCW631AR	SWITCH h3+ P630 4x630A

UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3191.04.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	No
Scope and classification fully covers the product (case 1 of Hager Group risk analysis):	Yes
Comments :	
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	Risk analysis 22.2505.04.22
Certificate(s) / test report(s):	CB test certificate NL_80141 / Test report No. 2258257.50 DMS039873
Mark approval(s):	No mark approvals
Product documentation :	See Hager website
Comments:	BS EN Standard requirements are identical to EN Standards