

**UKCA DECLARATION OF CONFORMITY No.**

**We** Hager Electro SAS  
BP3  
67215 OBERNAI CEDEX - FRANCE

**Declare that the product(s)**

**Designation**

MCCB H400 ELE

**Type reference(s)**

HED, HND Range

**Trademark**

Hager

**is (are) in conformity with the relevant United Kingdom legislation:**

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
  - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
  - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
- .....
- .....

**Standard(s) and/or relevant document(s) to which conformity is declared**

*Standard number + relevant amendments together with the edition dates*

**BS EN 60947-2:2017+A1:2020**

**BS EN IEC 63000:2018**

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

**This declaration of conformity is issued under the sole responsibility of the manufacturer.**

**On behalf of Hager Electro SAS**

**Name of signatory**

Mr Eric Boivin

**Function of signatory**

Certification Manager

**Place and date of issue**

Obernai, 20th June 2022

**Signature**



## UKCA DECLARATION OF CONFORMITY

No. 22\_3249\_06\_22

### Type references

Product Reference	Product Description
HED400U	Disjoncteur H400 3 poles 400A Icu/Ics= 70/50kA LSI
HND250H	Disjoncteur H400 3 poles 250A Icu/Ics= 50/50kA LSI
HND400H	Disjoncteur H400 3 poles 400A Icu/Ics= 50/50kA LSI
HED250H	Disjoncteur H400 3 poles 250A Icu/Ics= 70/50kA LSI
HED400H	Disjoncteur H400 3 poles 400A Icu/Ics= 70/50kA LSI
HED401U	Disjoncteur H400 4 poles 400A Icu/Ics= 70/50kA LSI
HND251H	Disjoncteur H400 4 poles 250A Icu/Ics= 50/50kA LSI
HND401H	Disjoncteur H400 4 poles 400A Icu/Ics= 50/50kA LSI
HED251H	Disjoncteur H400 4 poles 250A Icu/Ics= 70/50kA LSI
HED401H	Disjoncteur H400 4 poles 400A Icu/Ics= 70/50kA LSI
HED401G	Disjoncteur H400 4 poles 400A plug in Icu/Ics= 70/50kA LSI
HED400G	Disjoncteur H400 3 poles 400A plug in Icu/Ics= 70/50kA LSI
HED401F	Disjoncteur H400 4 poles 400A Draw out Icu/Ics= 70/50kA LSI

## UKCA DECLARATION OF CONFORMITY

No. 22\_3249\_06\_22

### Evidence (s)

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK ( <a href="https://www.gov.uk/guidance/designated-standards">https://www.gov.uk/guidance/designated-standards</a> ) are used:	Yes
Scope and classification fully covers the product (case 1 of Hager Group risk analysis):	Yes
Comments :	
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <a href="#">DMS034433</a> - Hager Group risk analysis)	Risk analysis 22.1870.06.22
Certificate(s) / test report(s):	CB test certificate No. NL-64834 and Test report No. 2243599.61 Certificate No. KRC 5917-1c Certificate No. KRC 15358f Supplier Compliance Certificate KRC 15235
Mark approval(s):	No marks
Product documentation :	See on Hager website
Comments:	BS EN Standard requirements are identical to EN Standard

## UKCA DECLARATION OF CONFORMITY

No. 22\_3249\_06\_22

### Evidence (s)

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

#### Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 60947-2:2006	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	01/01/2021	0009/21
-----------------------	-----------------	---	------------	---------

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 60947-2:2006	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	01/01/2021	0007/21
-----------------------	-----------------	---	------------	---------

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------