

UKCA DECLARATION OF CONFORMITY No. 22_3298_04_22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Contact auxiliaire / Déclencheur manque de tension - à émission -
surtension - combiné à manque de tension et surtension
Auxiliary contacts / Shunt trip - Undervoltage release / Overvoltage
Release / Combined Overvoltage & undervoltage Release

Type reference(s)

MZ201 / MZ202 / MZ221 / MZ203 / MZ204 / MZ210 / MZ205 / MZ206 /
MZ209 / MZ212 / MZ216 / MZ214 / MZ215 / CZ001

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 62019: 1999 + A1: 2003 + A11: 2005 + A12: 2014
BS EN 50550: 2011-02 + A1: 2014-09
BS EN 60947-5-1 : 2017-12
BS EN 60947-2 : 2017-10 + A1 : 2020-02
BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Mr Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, 26th april 2022

Signature

UKCA DECLARATION OF CONFORMITY

No. 22_3298_04_22

Type references

Product Reference	Product Description
MZ201	Auxiliary Contact 1O+1F 230V AC
MZ202	Contact Signal Default 1O+1F 230V AC
MZ221	Low Level Auxiliary Contact 1F+1O 5/10mA 12/48V AC/DC
MZ203	Shuntr trip Release 230-415V AC 110-130V DC
MZ204	Shunt trip Release 24-48V AC 12-48V DC
MZ210	
MZ205	Undervoltage release 48V DC
MZ206	Undervoltage release 230V AC
MZ209	Overvoltage release 230V AC
MZ212	
MZ216	
MZ214	Déclencheur combiné surtension/manque de tension Minimum manque de tension: 60 V AC Maximum manque de tension: 230 V AC Surtension: 270V AC
MZ215	Déclencheur combiné surtension/manque de tension Minimum manque de tension: 65 V AC Maximum manque de tension: 230 V AC Surtension: 267 V AC
CZ001	Auxiliary Contact for RCCB (1NO+1NC) 6A 240V AC

UKCA DECLARATION OF CONFORMITY

No. 22_3298_04_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	No Yes Designated After 2016
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	risk analysis 22.1239.04.22
Certificate(s) / test report(s):	CB test certificate NL_75688 CB test certificate NL_74994 EN 50550 Check List test report MZ214 MZ215 EN 50550 Check List test report MZ216 LB_14_0161 MR_14_0016 VDE license for RCCB Nr 40010710 – 40047956 – 40010738 – 40010770 – 40051393 - 40047947 – 40047952 - 40051600
Mark approval(s):	No mark approvals
Product documentation :	See Hager website
Comments:	None

UKCA DECLARATION OF CONFORMITY

No. 22_3298_04_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------