

UKCA DECLARATION OF CONFORMITY No. 23.3237.11.23

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Motor-Protective Circuit-Breaker (MPCB) / Auxiliaries / Accessories

Type reference(s)

MM5xxN - MZ5xxN

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

EN 60947-1: 2007 + A1: 2011 + A2: 2014
EN 60947-2 : 2017 + A1: 2020
EN 60947-4-1 : 2019 + AC: 2020
EN 60947-5-1 : 2017 + AC : 2020
EN 60947-5-5: 1997 +A1: 2005 + A11: 2013 + A2: 2017
EN ISO 13850: 2015
EN 50495: 2010
EN 60079-0: 2018
EN 63000: 2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Eric Boivin

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 7th november 2023

Signature



UKCA DECLARATION OF CONFORMITY

No. 23.3237.11.23

Type references

Type references	Désignation
MM501N	MPCB 0.1...0.16A
MM502N	MPCB 0.16...0.25A
MM503N	MPCB 0.25...0.4A
MM504N	MPCB 0.4...0.63A
MM505N	MPCB 0.63...1.0A
MM506N	MPCB 1.0...1.6A
MM507N	MPCB 1.6...2.5A
MM508N	MPCB 2.5...4.0A
MM509N	MPCB 4.0...6.3A
MM510N	MPCB 6.3...10.0A
MM511N	MPCB 10.0...16.0A
MM512N	MPCB 16.0...20.0A
MM513N	MPCB 20.0...25.0A
MM514N	MPCB 25.0...32.0A
MM520N	MPCB 3P 10-16 A
MM521N	MPCB 3P 16-25 A
MM522N	MPCB 3P 25-32 A
MM523N	MPCB 3P 32-40 A
MM524N	MPCB 3P 40-50 A
MM525N	MPCB 3P 50-58 A
MM526N	MPCB 3P 55-63 A
MZ520N	Lateral auxiliary contact 1M1B for MPCB
MZ521N	Enclosure for MPCB
MZ522N	Front auxiliary contact 1M install. for MPCB
MZ523N	Shunt release for MPCB
MZ527N	Trip Indicator switch for MPCB
MZ528N	Undervoltage release for MPCB
MZ529N	Undervoltage release for MPCB
MZ530N	External emergency stop button
MZ531N	External emergency stop button w. key
MZ532N	Lockable handle

UKCA DECLARATION OF CONFORMITY

No. 23.3237.11.23

Evidence(s)

Documents listed below have been developed to assure that all essential requirements of applied directive(s) are fulfilled:

If the product is not in the scope of Radio Equipment directive, fulfil table 1a, if yes fulfil table.

Table 1a Risk Assessment for Equipment without Radio		Applicable: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	Yes		
Scope and classification fully covers the product (case 1 of Hager Group risk analysis) :	Yes		
Comments :			
Hager Group risk analysis: Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	Not applicable		

Table 1b Risk Assessment for Radio equipment		Applicable: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Hager Group risk assessment: Fill document DMS063155			

Evidence(s) / Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives

Certificate(s) / test report(s):	CE 2300111 / CE 2100203 / CE 2100425 / CE2300145 / manufacturer declaration 17_05_2023 / RAPPORT AK-PKZ0_2023
Mark approval(s):	No mark approval
Product documentation :	See HAGER website
Comments:	None

Signature (technical design)

Name of signatory

Francis DIEBOLD

Place and date of issue

Obernai, 7th november 2023

Function of signatory

Engineering Director / Manager

Signature

