

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0860

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

DTVA3000 Intelligent Analogue Addressable Category P Heat Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Cooper Securite SAS
Parc Européen d'Entreprises II
Rue Beethoven
BP 10184
63204 Riom Cedex
France

SC Cooper Industries Romania SRL
Zona Industrială NV.
Str. III, NR 12
Arad
310510
Romania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors -Point heat detectors EN 54-17:2005 Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 05 November 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of Issue: 21 October 2022

Issue number 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0860**DTVA3000 Intelligent Analogue Addressable Category P Heat Detector with Short Circuit Isolator****Heat Classifications:**

Category A1R

Category BS

Category CS

Bases:

NUG30256 Single contact standard analogue addressable mounting base
NUG30258 Double contact standard analogue addressable mounting base



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of issue: 21 October 2022

Issue number: 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie