

1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 EC - Type Examination Certificate Number: **Baseefa13ATEX0233X**

4 Equipment or Protective System: **Type DB3BE GD Sounder & DB4BE GD Loudspeaker**

5 Manufacturer: **Cooper MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Baseefa, Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. **GB/BAS/ExTR13.0247/00**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0: 2012
EN 60079-1: 2007
EN 60079-7: 2007
EN 60079-31: 2009

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

Ex II 2GD Ex de IIC T4 Gb (T_{amb} = -50°C to +70°C)*
Ex tb IIC T135°C Db IP66 (T_{amb} = -50°C to +70°C)* *See Schedule

Baseefa Customer Reference No. **0676**

Project File No. **12/0368**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR
GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa13ATEX0233X

15 Description of Equipment or Protective System

The DB4BE GD Loudspeaker may be rated up to 100V at either 8W, 15W or 25W and comprises a cylindrical body and covers all moulded in Glass reinforced polyester. The front cover is an irregular shape which when fitted forms a chamber for the speaker driver assembly and is permanently sealed/filled with a potting compound. In the front of this cover is a fine stainless steel mesh pressed metal wire element to facilitate sound transmission.

The circular rear cover closes an Ex e terminal enclosure and is secured by three M5 stainless steel screws. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The Ex e chamber houses a terminal block of either 4, 6 or 8 (2x4) Ex e connections, Component Certified to SIRA01ATEX3247U.

The base of this enclosure then forms the cover of the flameproof chamber and with integral cables passing through a potted bushing arrangement. The terminal enclosure is fixed with six M5 x 20mm long stainless steel socket head screws of grade A2-70 minimum. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The flameproof chamber houses an assembly of a transformer and a control/terminal PCB.

Up to two M20 or M25 cable entries are provided in the side of the enclosure to accommodate suitably certified cable entry devices.

A plastic horn assembly (with either a long or short flare) is fitted externally to the front, and along the sides, of the enclosure, together with a mounting bracket. When the short flare is fitted the ingress protection rating is reduced to IP65.

The 8W units are marked with a T4/T135°C ($T_{amb} = -50^{\circ}\text{C}$ to $+70^{\circ}\text{C}$) and/or T5/T100°C ($T_{amb} = -50^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T6/T85°C ($T_{amb} = -50^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

The 15W units are marked with a T4/T135°C ($T_{amb} = -50^{\circ}\text{C}$ to $+65^{\circ}\text{C}$) and/or T5/100°C ($T_{amb} = -50^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T6/T85°C ($T_{amb} = -50^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

The 25W units are marked with a T4/T135°C ($T_{amb} = -50^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T5/T100°C ($T_{amb} = -50^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

Variation 0.1

The DB3BE GD Sounder is rated up to 254V, 15W and is identical in construction to the above Loudspeaker except that the flameproof chamber contains different components, including sound generating PCB's (with both AC & DC variants).

The Sounders are marked with a T4/T135°C ($T_{amb} = -50^{\circ}\text{C}$ to $+70^{\circ}\text{C}$) and/or T5/100°C ($T_{amb} = -50^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T6/T85°C ($T_{amb} = -50^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination

16 Report Number

Confidential Report Number GB/BAS/ExTR13.0247/00

17 Specific Conditions of Use

1. For replacement purposes the cover fixing screws shall be of stainless steel grade A2-70 or stronger
2. Painting and surface finishes, other than those applied by the manufacturer, are not permitted
3. When the unit is used in dust atmospheres the cable entries used shall be sealed to maintain the IP6X rating, in accordance with the applicable installation codes.
4. Not more than one single or multiple strand wiring lead shall be connected into either side of any terminal, unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.
5. Leads connected to the terminals shall be insulated for at least 275V and this insulation shall extend to within 1mm of the metal of the terminal throat.
6. Minimum creepage and clearance distances between the terminals and adjacent conductive parts (including cable entry devices) must be at least 6mm.
7. All terminal screws, used and unused, shall be tightened down.

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

Number	Issue	Date	Description
# 399-101 Sheets 1 to 3	A	22/11/2013	General Arrangement, DB4B Speaker
# 419-107	A	22/11/2013	General Arrangement, DB3B Sounder
@ 419-108	A	22/11/2013	General Arrangement, Ex e Chamber
* 399-105	A	14-10-13	Certification Labels, DB4BE Ex de & Ex tb Speaker
* 419-112	A	14-10-13	Certification Labels, DB3BE Ex de & Ex tb Sounder
^ 419-177	A	22/11/2013	Pressed Wire Element, Extra Fine Mesh

Drawing common to this certificate and IECEX BAS 13.0112X, IECEX BAS 13.0113X, IECEX BAS 13.0114X and IECEX BAS 13.0115X together with Baseefa13ATEX0229X, Baseefa13ATEX0231X, and Baseefa13ATEX0232X and are held on IEC Ex BAS13.0112X

@ Drawing common to this certificate and IECEX BAS 13.0114X, IECEX BAS 13.0115X and Baseefa13ATEX0232X and are held on IEC Ex BAS 13.0114X

* Drawing common to this certificate and IECEX BAS 13.0115X and is held on the latter.

^ Drawing common to this certificate and IECEX BAS 13.0113X, IECEX BAS 13.0115X and Baseefa13ATEX0231X and are held on IEC ExBAS13.0113X.

1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: **Baseefa13ATEX0233X/1**

4 Equipment or Protective System: **Type DB3BE GD Sounder & DB4BE GD Loudspeaker**

5 Manufacturer: **Cooper MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**

7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa13ATEX0233X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. 0676

Project File No. 14/0221

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited


Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


P R S SINCLAIR
GENERAL MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number Baseefa13ATEX0233X/1**

15 **Description of the variation to the Equipment or Protective System**

Variation 1.1

An increase in the maximum pore size of the fine mesh stainless steel pressed wire element.

16 **Report Number**

Baseefa Confidential Report No. GB/BAS/ExTR14.0082/00

17 **Specific Conditions of Use**

None additional to those listed previously

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

Number	Issue	Date	Description
419-177	B	10/03/14	Pressed wire Element, Extra Fine Mesh, Basket Weave

This drawing is common to IECEx BAS 13.0113X, IECEx BAS 13.0115X and Baseefa13ATEX0231X.

1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

- 3** Supplementary EC - Type Examination Certificate Number: **Baseefa13ATEX0233X/2**
- 4** Equipment or Protective System: **Type DB3BE GD Sounder & DB4BE GD Loudspeaker**
- 5** Manufacturer: **Copper MEDC Limited**
- 6** Address: **Unit B, Sutton Parkway, Oddicroft, Sutton-in-Ashfield, NG17 5FB**
- 7** This supplementary certificate extends EC – Type Examination Certificate No. **Baseefa13ATEX0233X** to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. **0676**

Project File No. **14/0834**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR
GENERAL MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number Baseefa13ATEX0233X/2**

15 **Description of the variation to the Equipment or Protective System**

Variation 2.1

To allow the option of including an additional internal earth terminal within the chamber of the equipment.

16 **Report Number**

Baseefa certification report: GB/BAS/ExTR14.0304/00

17 **Specific Conditions of Use**

See previous certificates.

1. If used, internal optional earthing material shall be anti-corrosive.

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

Number	Sheet	Issue	Date	Description
*419-108	1 of 1	B	17-09-14	DB3B/DB4B EXE CHAMBER ATEX/IECEX CERTIFICATION GA

*This drawing is common to this certificate and IECEX BAS 13.0114X, IECEX BAS 13.0115X and Baseefa13ATEX0232X and is held on IECEX BAS 13.0114X.

1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: Baseefa13ATEX0233X/3

4 Equipment or Protective System: Type DB3BE GD Sounder & DB4BE GD Loudspeaker

5 Manufacturer: Copper MEDC Limited

6 Address: Unit B, Sutton Parkway, Oddicroft, Sutton-in-Ashfield, NG17 5FB

7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa13ATEX0233X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. 0676

Project File No. 14/0862

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa13ATEX0233X/3

15

Description of the variation to the Equipment or Protective System

Variation 2.1

To allow the correction of note 3 on drawing number 419-177, so as to adjust the minimum sinter weight from 18.3g to 16.4g. This has no effect upon the explosion type of protections offered by the equipment.

16

Report Number

Baseefa certification report: GB/BAS/ExTR14.0314/00

17

Specific Conditions of Use

See previous certificates.

18

Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19

Drawings and Documents

Number	Sheet	Issue	Date	Description
*419-177	1 of 1	C	16/10/14	SINTER SS MESH IIC+IIIC CERETIFED DRAWING

*This drawing is common to this certificate and IECEX BAS 13.0113X, IECEX BAS 13.0115X and Baseefa13ATEX0231X and is held on IECEX BAS 13.0113X.

1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: **Baseefa13ATEX0233X/4**

4 Equipment or Protective System: **Type DB3BE GD Sounder & DB4BE GD Loudspeaker**

5 Manufacturer: **Cooper MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**

7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa13ATEX0233X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. 0676

Project File No. 15/0646

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa13ATEX0233X/4

15 Description of the variation to the Equipment or Protective System

Variation 4.1

To permit the amendment to change the terminal conductor size from 3.5mm² to 4mm².

Variation 4.2

Minor admin changes to the drawings not affecting certification.

16 Report Number

SGS Baseefa Report Number GB/BAS/ExTR15.0256/00

17 Specific Conditions of Use

None additional to those listed previously

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
399-101	1 to 3	C	04/09/2015	DB4B EXD Speaker, General Assembly

This drawing is common to Baseefa13ATEX0229X, Baseefa13ATEX0231X, Baseefa13ATEX0232X, Baseefa13ATEX0233X and IECEx BAS 13.0115X, IECEx BAS 13.0114X, IECEx BAS 13.0113X and IECEx BAS 13.0112X and held with the latter.

1 **SUPPLEMENTARY EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 Supplementary EU - Type Examination Certificate Number: **Baseefa13ATEX0233X/6**

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **Type DB3BE GD Sounder and DB4BE GD Loudspeaker**

5 Manufacturer: **Eaton MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**

7 This supplementary certificate extends EC – Type Examination Certificate No. **Baseefa13ATEX0233X** to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that the product, as modified by this supplementary certificate, has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

9 Item 9 of the original Certificate is replaced by “Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0: 2018 EN 60079-1: 2014 EN 60079-7: 2015 EN 60079-31: 2014

except in respect of those requirements listed at item 18 of the Schedule.”

12 The marking of the equipment has changed from the original Certificate and shall include the following:

Ⓢ II 2GD **Ex db eb IIC T* Gb**
Ex tb IIIC T*°C Db IP6**
(Tamb = -50°C to +°C)
***See Schedule for T class & ambient combination.**
**** See Schedule for IP marking**

SGS Baseefa Customer Reference No. **0676**

Project File No. **18/0757**


This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail baseefa@sgs.com web site www.sgs.co.uk/sgsbaseefa
Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR
TECHNICAL MANAGER

On behalf of SGS Baseefa Limited

M POWNEY
Certification
Manager

13

Schedule

14

Certificate Number Baseefa13ATEX0233X/6

15 Description of the variation to the Product

Variation 6.1

To remove the use of an adhesive, and allow an alternative method of Ex d cover gasket retention, across all models of DB3B & DB4B.

Variation 6.2

To correct the cable temperature rise value as indicated on the certification labels

Variation 6.3

To allow an optional IIC IIIC sinter across all models of DB3B & DB4B

Variation 6.4

To allow an increase operating ambient temperature by across all models DB3B & DB4B

Variation 6.5

To assess Type DB3BE GD Sounder and DB4BE GD Loudspeaker against the standards EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-7:2015 and EN 60079-31:2014.

The product description is amended as follows

The DB4BE GD Loudspeaker may be rated up to 100V at either 8W, 15W or 25W and comprises a cylindrical body and covers all moulded in Glass reinforced polyester. The front cover is an irregular shape which when fitted forms a chamber for the speaker driver assembly and is permanently sealed/filled with a potting compound. In the front of this cover is a fine stainless steel mesh pressed metal wire element to facilitate sound transmission.

The circular rear cover closes an Ex e terminal enclosure and is secured by three M5 stainless steel screws. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The Ex e chamber houses a terminal block of either 4, 6 or 8 (2x4) Ex e connections, Component Certified to IECEx SIR 05.0035U.

The base of this enclosure then forms the cover of the flameproof chamber and with integral cables passing through a potted bushing arrangement. The terminal enclosure is fixed with six M5 x 20mm long stainless steel socket head screws of grade A2-70 minimum. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The flameproof chamber houses an assembly of a transformer and a control/terminal PCB.

Up to two M20 or M25 cable entries are provided in the side of the enclosure to accommodate suitably certified cable entry devices.

A plastic horn assembly (with either a long or short flare) is fitted externally to the front, and along the sides, of the enclosure, together with a mounting bracket. When the short flare is fitted the ingress protection rating is reduced to IP65.

Variation 0.1

The DB3BE GD Sounder is rated up to 254V, 15W and is identical in construction to the above Loudspeaker except that the flameproof chamber contains different components, including sound generating PCB's (with both AC & DC variants).

The equipment may be marked with one or multiple combinations, as below:

MODEL	POWER	TEMPERATURE MARKING
DB4BE GD	8W	T4/T135°C (T _{amb} -50°C to +85°C)
		T5/T100°C (T _{amb} -50°C to +55°C)
		T6/T85°C (T _{amb} -50°C to +40°C)
	15W	T3/T200°C (T _{amb} -50°C to +85°C)
		T4/T135°C (T _{amb} -50°C to +70°C)
		T5/T100°C (T _{amb} -50°C to +40°C)
25W	T4/T135°C (T _{amb} -50°C to +70°C)	
	T5/T100°C (T _{amb} -50°C to +40°C)	
DB3BE GD	15W	T4/T135°C (T _{amb} -50°C to +85°C)
		T5/T100°C (T _{amb} -50°C to +55°C)
		T6/T85°C (T _{amb} -50°C to +40°C)

MODEL	IP RATING	FLARE OPTIONS
DB4BE GD	IP66	When fitted with long flare
DB3BE GD		
	IP65	When fitted with short flare

16 Report Number

SGS Baseefa test report GB/BAS/ExTR19.0013/00

17 Specific Conditions of Use

None additional to those listed previously

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is affected as follows.

Clause	Subject
1.2.7	LDV requirements.
1.2.8	Overloading of equipment (protection relays, etc)
1.4.1	External effects.
1.4.2	Aggressive substances etc.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
399-105	1	B	28/01/19	DB4B Ex de GD SPEAKER ATEX/IECEX CERT LABEL DETAIL
419-112	1	B	28/01/19	DB3B Ex de GD SOUNDER ATEX/IECEX CERT LABEL DETAIL

These drawings are common to, and held with, IECEx BAS 13.0115X



Number	Sheet	Issue	Date	Description
399-101	1-3	D	30/11/18	DB4B Ex d G SPEAKER ATEX/IECEX CERTIFICATION GA
419-346	1	A	17/01/2019	SINTER – HYBRID MESH SS IIC + IIIC

These drawings are common to Baseefa13ATEX0229X, IECEX BAS 13.0113X, Baseefa13ATEX0231X, IECEX BAS 13.0114X, Baseefa13ATEX0232X, IECEX BAS 13.0115X, Baseefa13ATEX0233X, and held with IECEX BAS 13.0112X

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 EU - Type Examination Certificate Number: **Baseefa13ATEX0233X – Issue 7**

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **Type DB3BE GD Sounder & DB4BE GD Loudspeaker**

5 Manufacturer: **Eaton MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**

7 This re-issued certificate extends EC Type Examination Certificate No. **Baseefa13ATEX0233X** to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Fimko Oy, Notified Body number 0598, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

8.1 The original certificate was issued by SGS Baseefa Ltd (UK Notified Body 1180). It, and any supplements previously issued by SGS Baseefa Ltd have been transferred to the supervision of SGS Fimko Oy (EU Notified Body 0598). The original certificate number is retained.

The examination and test results are recorded in confidential Report No. – See Certificate history

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0: 2018 EN 60079-1: 2014 EN IEC 60079-7: 2015 + A1: 2018 EN 60079-31: 2014

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following:

⊕ II 2GD Ex db eb IIC T* Gb (*See Schedule for T class & ambient combination)

Ex tb IIIC T*°C Db IP6 (**See Schedule for IP marking)**

(Tamb = -50°C to +°C)

SGS Fimko Oy Customer Reference No. **0676**

Project File No. **21/0314**

This document is issued by the Company subject to their General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of their intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Oy

Takomotie 8
FI-00380 Helsinki, Finland
Telephone +358 (0)9 696 361
e-mail sgs.fimko@sgs.com
web site www.sgs.fi

Business ID 0978538-5 Member of the SGS Group (SGA SA)



Tuomas Hänninen
SGS Fimko Oy

13

Schedule

14

Certificate Number Baseefa13ATEX0233X – Issue 7

15 Description of Product

The DB4BE GD Loudspeaker may be rated up to 100V at either 8W, 15W or 25W and comprises a cylindrical body and covers all moulded in Glass reinforced polyester. The front cover is an irregular shape which when fitted forms a chamber for the speaker driver assembly and is permanently sealed/filled with a potting compound. In the front of this cover is a fine stainless steel mesh pressed metal wire element to facilitate sound transmission.

The circular rear cover closes an Ex e terminal enclosure and is secured by three M5 stainless steel screws. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The Ex e chamber houses a terminal block of either 4, 6 or 8 (2x4) Ex e connections, Component Certified to TUV 18 ATEX 8209 U.

The base of this enclosure then forms the cover of the flameproof chamber and with integral cables passing through a potted bushing arrangement. The terminal enclosure is fixed with six M5 x 20mm long stainless steel socket head screws of grade A2-70 minimum. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The flameproof chamber houses an assembly of a transformer and a control/terminal PCB.

Up to two M20 or M25 cable entries are provided in the side of the enclosure to accommodate suitably certified cable entry devices.

A plastic horn assembly (with either a long or short flare) is fitted externally to the front, and along the sides, of the enclosure, together with a mounting bracket. When the short flare is fitted the ingress protection rating is reduced to IP65.

The equipment may be marked with one or multiple combinations, as below:

MODEL	POWER	TEMPERATURE MARKING
DB4BE GD	8W	T4/T135°C (Tamb -50°C to +85°C)
		T5/T100°C (Tamb -50°C to +55°C)
		T6/T85°C (Tamb -50°C to +40°C)
	15W	T3/T200°C (Tamb -50°C to +85°C)
		T4/T135°C (Tamb -50°C to +70°C)
		T5/T100°C (Tamb -50°C to +40°C)
25W	T4/T135°C (Tamb -50°C to +70°C)	
	T5/T100°C (Tamb -50°C to +40°C)	

MODEL	POWER	TEMPERATURE MARKING
DB3BE GD	15W	T4/T135°C (Tamb -50°C to +85°C)
		T5/T100°C (Tamb -50°C to +55°C)
		T6/T85°C (Tamb -50°C to +40°C)

MODEL	IP RATING	FLARE OPTIONS
DB4BE GD	IP66	When fitted with long flare
DB3BE GD	IP65	When fitted with short flare

16 Report Number

See Certificate history

17 Specific Conditions of Use

1. For replacement purposes the cover fixing screws shall be of stainless steel grade A2-70 or stronger
2. Painting and surface finishes, other than those applied by the manufacturer, are not permitted
3. When the unit is used in dust atmospheres the cable entries used shall be sealed to maintain the IP6X rating, in accordance with the applicable installation codes.
4. Not more than one single or multiple strand wiring lead shall be connected into either side of any terminal, unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.
5. Leads connected to the terminals shall be insulated for at least 275V and this insulation shall extend to within 1mm of the metal of the terminal throat.
6. Minimum creepage and clearance distances between the terminals and adjacent conductive parts (including cable entry devices) must be at least 6mm.
7. All terminal screws, used and unused, shall be tightened down.
8. If used internal optional earthing material shall be anti-corrosive.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
1.2.7	LVD type requirements	Standards require manufacturer's declaration, supplied.
1.2.8	Overloading of equipment (protection relays, etc.)	Covered by installation rules and manufacturer's instructions
1.4.1	External effects	The Purchaser should make the manufacturer aware of such issues. Covered in Instructions
1.4.2	Aggressive substances, etc.	The Purchaser should make the manufacturer aware of such issues. Covered in Instructions

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Issue	Date	Description
**419-108	E	15-09-20	DB3B / DB4B EXE Chamber ATEX / IECEX CERTIFICATION GA

Current drawings which remain unaffected by this issue:

Number	Issue	Date	Description
*399-101	D	30/11/18	DB4B Ex d G SPEAKER ATEX/IECEX CERTIFICATION GA
*419-346	A	17/01/2019	SINTER – HYBRID MESH SS IIC + IIIC
*419-107	A	22/11/2013	General Arrangement, DB3B Sounder
#399-105	B	28/01/19	DB4B Ex de GD SPEAKER ATEX/IECEX CERT LABEL DETAIL
#419-112	B	28/01/19	DB3B Ex de GD SOUNDER ATEX/IECEX CERT LABEL DETAIL
~419-177	C	16/10/14	SINTER SS MESH IIC+IIIC CERETIFED DRAWING

* Drawing common to this certificate and IECEX BAS 13.0112X, IECEX BAS 13.0113X, IECEX BAS 13.0114X and IECEX BAS 13.0115X together with Baseefa13ATEX0229X, Baseefa13ATEX0231X, and Baseefa13ATEX0232X and are held on IEC Ex BAS13.0112X

** Drawing common to this certificate and IECEX BAS 13.0114X, IECEX BAS 13.0115X and Baseefa13ATEX0232X and are held on IEC Ex BAS 13.0114X

Drawing common to this certificate and IECEX BAS 13.0115X and is held on the latter.

~ Drawing common to this certificate and IECEX BAS 13.0113X, IECEX BAS 13.0115X and Baseefa13ATEX0231X and are held on IEC ExBAS13.0113X.

20 Certificate History

Certificate No.	Date	Comments
Baseefa13ATEX0233X	2 December 2013	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2012, EN 60079-1: 2007, EN 60079-7: 2007 and EN 60079-31: 2009. SGS Baseefa Certification Report GB/BAS/ExTR13.0247/00
Baseefa13ATEX0233X/1	24 March 2014	To permit an increase in the maximum pore size of the fine mesh stainless steel pressed wire element. SGS Baseefa Certification Report GB/BAS/ExTR14.0082/00
Baseefa13ATEX0233X/2	27 October 2014	This issue of the certificate is to allow the option of including an additional internal earth terminal within the chamber of the equipment. SGS Baseefa Certification Report GB/BAS/ExTR14.0304/00
Baseefa13ATEX0233X/3	29 October 2014	To allow the correction of note 3 on drawing number 419-177, so as to adjust the minimum sinter weight from 18.3g to 16.4g. SGS Baseefa Certification Report GB/BAS/ExTR14.0314/00.
Baseefa13ATEX0233X/4	8 September 2015	To permit the amendment to change the terminal conductor size from 3.5mm ² to 4mm ² along with minor admin changes to the drawings not affecting certification. SGS Baseefa Certification Report GB/BAS/ExTR15.0256/00.
Baseefa13ATEX0233X/5	11 May 2018	To allow optional configurations of the internal and external earthing arrangement. SGS Baseefa Certification Report GB/BAS/ExTR18.0102/00.
Baseefa13ATEX0233X/6	5 February 2019	This issue of the certificate is: <ul style="list-style-type: none"> • To remove the use of an adhesive and allow an alternative method of Ex d cover gasket retention, across all models of DB3B & DB4B. • To correct the cable temperature rise value as indicated on the certification labels • To allow an optional IIC IIIC sinter across all models of DB3B & DB4B • To allow an increase operating ambient temperature by across all models DB3B & DB4B • To assess Type DB3BE GD Sounder and DB4BE GD Loudspeaker against the standards EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-7:2015 and EN 60079-31:2014. SGS Baseefa Certification Report GB/BAS/ExTR19.0013/00.
Baseefa13ATEX0233X Issue 7	NN July 2021	To change the existing Ex e terminal Block's certificate numbers referenced and assess the product against the requirements of EN IEC 60079-0: 2015+A1: 2018. SGS Baseefa Certification Report GB/BAS/ExTR21.0087/00.
For drawings applicable to each issue, see original of that issue.		