MITSUBISHI ELECTRIC
AIR CONDITIONING SYSTEMS EUROPE LTD.
NETTLEHILL ROAD
HOUSTOUN INDUSTRIAL ESTATE
LIVINGSTON, EH54 5EQ, U.K.
Telephone: +44 (0)1506 445500
Fax: +44 (0)1506 445511

DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer.

We MITSUBISHI ELECTRIC AIR CONDITIONING SYSTEMS EUROPE LTD. NETTLEHILL ROAD HOUSTOUN INDUSTRIAL ESTATE LIVINGSTON EH54 5EQ SCOTLAND, UNITED KINGDOM

are the manufacturer of below models and hereby declares under its sole responsibility that the AIR CONDITIONERS and HEAT PUMPS described below for use in residential, commercial and light-industrial environments:

MITSUBISHI ELECTRIC, PUZ-WZ85VAA, PUZ-WZ85VAA-BS, PUZ-WZ100VAA, PUZ-WZ100VAA-BS, PUZ-WZ120VAA, PUZ-WZ120VAA-BS, PUZ-WZ85YAA, PUZ-WZ85YAA-BS, PUZ-WZ100YAA, PUZ-WZ100YAA-BS, PUZ-WZ120YAA, PUZ-WZ120YAA-BS

comply with the provisions of the following European Directives, the harmonised standards and the specifications.:

Directives	Standards / Specifications
2014/35/EU: Low Voltage Directive	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012, EN 62233: 2008, IEC 60335-1:2010 / A1:2013 / A2:2016, IEC 60335-2-40:2022
2006/42/EC: Machinery Directive	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012
2014/30/EU: Electromagnetic Compatibility Directive	EN 55014-1: 2017 / A11:2020, EN 61000-3-12: 2011, EN 61000-3-2: 2014, EN 61000-3-3: 2013, EN 55014-2: 1997 / A1: 2001 / A2: 2008 (Category IV)
2011/65/EU, (EU) 2015/863 and (EU) 2017/2102: RoHS Directive	EN IEC 63000: 2018
2009/125/EC: Energy-related Products Directive and Regulation (EU) No 813/2013	EN 12102-1:2013, EN 14511-1:2018, EN 14511-2:2018, EN 14511-3:2018, EN14511-4:2018, EN 14825:2018, EN 16147:2017

Please refer to http://erp.mitsubishielectric.eu/erp for more information of 2009/125/EC.

Information of 2014/68/EU Pressure Equipment

Pressure Component	Compressor	Category II
Applied conformity assessment procedure:	Internal manufacturing checks with monitoring of the final assessment (module D1)	
The monitoring is performed by the Notified Body:	BSI Group The Netherlands B.V. Say Building, John M. Keynesplein 9, 1066 EP Amsterdam, Netherlands	

Issued date: 5 November, 2024

Revised date: --- --- ---

Kengo Takahashi

Kengo TAKAHASHI
Manager, Quality Assurance Department
UNITED KINGDOM

CE2024C01