


ENERGY AND AUTOMATION

| Product designation | | | | Changeover Switch |
|--|---|-----------|---|----------------------|
| Product type designation | nn | | | GE |
| Number of poles | | | Nr. | 3 |
| Operating voltage type | | | | AC |
| Contact characteristics | | | | |
| IEC Conventional free | | | Α | 2000 |
| Rated insulation voltage | | | V | 1000 |
| Rated impulse withstan | | | kV | 12 |
| Operating current le | in remage cump | | | · - |
| operating earrorn to | AC21A | | | |
| | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, | 400V | Α | 2000 |
| | | 500V | Α | 2000 |
| | | 690V | Α | 1800 |
| | AC22A | | | |
| | | 400V | Α | 2000 |
| | | 500V | A | 1800 |
| | | 690V | A | 1600 |
| | AC23A | 3301 | | |
| | 7.0257. | 400V | Α | 1250 |
| | | 500V | Α | 900 |
| | | 690V | Α | 630 |
| Power dissipation per pole max | | | W | 59.6 |
| Rated operational pow | | | • | 00.0 |
| rated operational pow | 017102071 | 400V | kW | 692 |
| | | 690V | kW | 764 |
| Rated short time currer | nt (1s) low (rms) | 000 1 | kA | 50 |
| Making capacity AC23A 400V | | | A | 12500 |
| Breaking capacity AC23A 400V | | | A | 10000 |
| Mechanical life | SA 400 V | | | 3000 |
| Mechanical features | | | cycles | 3000 |
| | | | | |
| Operating position | | normal | | \/ortical plan |
| | | normal | | Vertical plan |
| Fixing a | | allowable | | Any |
| Fixing | | | | Screw |
| Terminals | | , | | D |
| | | type | | Bar |
| Timbing to the state of the sta | | screw | | M14 |
| Tightening torque for te | erminais | | | |
| A 1 4 4 10 10 10 10 10 10 10 10 10 10 10 10 10 | | max | Nm | 55 |
| Ambient conditions | | | | |
| Operating temperature | | | | |
| | | min | °C | -25 |
| | | max | °C | +55 |
| Storage temperature | | | | |
| | | min | °C | -40 |
| | | max | °C | +70 |
| Max altitude | | | m | 3000 |
| Wiring diagrams | | | | |
| | | | | |



ENERGY AND AUTOMATION



Certifications and compliance

Compliance

IEC/EN 60947-1

IEC/EN 60947-3

Certifications

EAC

ETIM classification

ETIM 8.0

EC000216 -Switch disconnector